

September 30, 2016

ADDENDUM NO. 3

TO PROSPECTIVE BIDDERS UNDER RFQ NO.1615, "TRAILER MOUNTED PORTABLE PUMP"

Notice is hereby given that RFQ No. 1615 of the East Bay Municipal Utility District has been revised as set forth below:

1. Specification 33 12 23.20-15, Section "A. General", No. 10.  
**Replace:** "Enclosure shall include a forced air circulation with inlet/out vents to the inside of the enclosure. The temperature inside the enclosure **shall not exceed 95 degrees F.**"  
  
**With:** "Enclosure shall include a forced air circulation with inlet/out vents to the inside of the enclosure. The temperature inside the enclosure **shall not exceed 104 degrees F.**"
2. **Bidder Question:** Is the programming of the Programmable Logic Controller (PLC) completed by the contractor?  
**Answer:** The RFQ scope does not include programming of the PLC.
3. The **date** of the bid opening has been changed to **October 7, 2016**. Time and bid opening location remain unchanged.
4. There will be no further questions accepted on this RFQ.

THIS ADDENDUM MUST BE SUBMITTED WITH THE BID.



Andrew A. Akelman  
Manager of Purchasing