

September 3, 2015

ADDENDUM NO. 2

TO PROSPECTIVE BIDDERS UNDER RFQ NO. 1604, "SAN PABLO RESERVOIR
RECREATION AREA DOCK AND RAMP REPLACEMENT "

Notice is hereby given that Proposal No. 1604 of the East Bay Municipal Utility District has been revised as set forth below.

Questions from the bid walk are answered as follows:

1. There is no specific budget amount associated with this project.
2. The winch system is to be replaced with the same number of winches and stands. Some are double and some are single. The wire rope and anchors will be reused or replaced by EBMUD, separately from this bid process.
3. The peddle boats and kayaks do not need individual slips. They are grouped together and secured to the dock on the north side of the main arm.
4. The concessionaire has removed the small regular fishing boats from the dock for the season due to low water levels. The dimensions of the boats are: 14'3" LOA (length overall), 64" beam, and 15" transom height.
5. The docks can have synthetic lumber for all the side boards.

THIS ADDENDUM MUST BE SUBMITTED WITH THE BID.



Andrew A. Akelman

Manager of Purchasing

375 ELEVENTH STREET , OAKLAND , CA 94607-4240 , TOLL FREE 1-866-40-EBMUD