

September 23, 2015

ADDENDUM NO. 1

TO PROSPECTIVE BIDDERS UNDER RFQ NO. 1528, "Power Building Electrical Equipment"

Notice is hereby given that Proposal No. 1528 of the East Bay Municipal Utility District has been revised as set forth below:

SPECIFICATION SECTION 26 05 91 – 15, Part 2.1, A. "Acceptable Manufacturers" add "Meyers Power Products, Inc."

SPECIFICATION SECTION 26 05 91 – 25, Part 2.3, B: Replace existing with:

B. The switches shall be UL 1008 listed for emergency use, bypass/isolation, delayed transition, three-phase, three-wire, three-cycle withstand closing rating, with 0.5 second short-time rating for coordination with the upstream feeder circuit breakers specified in Article 2.2 D and as follows.

SPECIFICATION SECTION 26 05 91 – 25, 2.3, C, No. 6, 6a and 6b Replace existing with:

6. Equip transfer switch with a permanently attached, safe, manual operator designed to prevent injury to personnel in the event the electrical operator should become energized during manual transfer.

- a. Provide a manual operator handle.
- b. Both power sources shall be disconnected before manual operation of the switch, using the switch handle.

THIS ADDENDUM MUST BE SUBMITTED WITH THE BID.


for
Andy Akelman
Manager of Purchasing