

August 28, 2017

ADDENDUM NO. 1

TO PROSPECTIVE BIDDERS UNDER RFQ NO. 1803, "**Granular Activated Carbon Filter Pressure Vessel System**"

Notice is hereby given that RFQ No. 1803 of the East Bay Municipal Utility District has been revised as set forth below:

Please read the following very carefully and note that the revisions to the RFQ language are shown in **bold underline**:

1. EXHIBIT D – TECHNICAL SPECIFICATIONS, 43 42 01 GRANULAR ACTIVATED CARBON (GAC) PRESSURE VESSEL FILTER SYSTEM

- Section 1.04.B.10 to be revised to read as follows:

"The vessel will be sized to contain 22,300 pounds of pH-stabilized Filtrasorb 400 GAC and to accommodate approximately 30% bed expansion within the straight side of the vessel."

- Section 1.04.B.11 – GAC Filter Design Criteria (table) to be revised to read as follows:

"Weight of GAC media Lbs **22,300**"

- Section 2.02.F.2.a through f on page 43 42 01-9 shall be revised, in its entirety, as follows:

"2. GAC design criteria:

a. Mesh: 12x40 mesh GAC

1) On 12 Mesh: 5% max

2) Thru 40 mesh: 4% max

b. Effective Size: 0.55 – 0.75 mm

c. Uniformity Coefficient: 1.9 (max)

d. Abrasion Number: 75 min

e. Iodine Number: 1000 mg/g (min)

f. Calgon Carbon Corp. pH-stabilized Filtrasorb 400, no substitute."

2. EXHIBIT A – RFQ RESPONSE PACKET, BID FORM

- The bid form included in the original RFQ shall be replaced, in its entirety, by the “BID FORM – REVISED” attached hereto. The “BID FORM - REVISED shall be submitted with your bid package.

DUE DATE, TIME, AND LOCATION SHALL REMAIN THE SAME WITH **BIDS DUE ON AUGUST 16, 2017 AT 1:30PM.**



Andrew A. Akelman
Manager of Purchasing

BID FORM- REVISED

Cost shall be submitted on this Bid Form as is. The prices quoted shall not include Sales Tax or Use Tax; said tax, wherever applicable, will be paid by the District to the contractor, if licensed to collect, or otherwise directly to the State.

No alterations or changes of any kind to the Bid Form(s) are permitted. **Bidders must submit pricing on all bid items in both Table 1 and Table 2.** RFQ responses that do not comply may be subject to rejection in total. The cost quoted below shall be the cost the District will pay for the term of any contract that is a result of this RFQ process.

Quantities listed herein are annual estimates based on past usage and are not to be construed as a commitment. No minimum or maximum is guaranteed or implied.

TABLE 1

Bid Item	Description	Unit of Measure	Estimated Quantity	Unit Cost	Total Cost
1	GAC Filter System	EA	1	N/A	\$
2	GAC filter Media (as described in EXHIBIT D – TECHNICAL SPECIFICATIONS, 43 42 01)	Lbs	<u>22,300</u>	\$	\$
3	Start-up Assistance, Mfg Inspection for proper installation and operation and Training on GAC System	LS	1	N/A	\$
4	Travel Costs, Factory Inspection, and Testing of GAC Filter System	LS	1	N/A	

TABLE 2 - ALTERNATE BID ITEM (may replace Bid Item 1 at the discretion of the District)

5	Cost of GAC Filter System Modified for Two Identical Tanks piped in Series and/or Parallel	LS	1	N/A	\$
---	--	----	---	-----	----