



REGULATIONS GOVERNING WATER SERVICE TO CUSTOMERS OF THE EAST BAY MUNICIPAL UTILITY DISTRICT

PAGE NUMBER: 08-A

SECTION 8 LIMITED SERVICE

An applicant for water service may not receive adequate water pressure where the building site of the Premises will be located at an elevation less than 75 feet below the overflow level of the reservoir providing such service, even though the service connection would be located on a water main with adequate capacity and proper pressure. As stated in these Regulations, Standard Service to such Premises is not reasonably available. However, a Limited Service may be granted for Premises located at such elevations under all of the following conditions:

1. The District has determined that providing a standard distribution system that would deliver adequate pressure to the Premises is not presently feasible.
2. To minimize-pressure loss and/or for individual storage and pumping facilities operation the applicant may request and the District may install a larger tap, lateral and meter than usually installed by the District for similar premises.
3. All rates and charges shall be based on the meter size.
4. The owner(s) of the premises shall agree in writing to accept a Limited Service consistent with what the District can furnish from its existing distribution system. This agreement shall be a covenant against the premises to be served and shall run with the land, and will be recorded by the District at the County Recorder's Office, thereby providing notice to subsequent owners.

In addition to the above requirements, the District recommends that the applicant install and maintain individual storage and pumping facilities (for example, a hydropneumatic system) and associated plumbing necessary to ensure an adequate water supply at the premises at all times. Such system and equipment shall be installed on the applicant's side of the meter, and at the applicant's own risk and expense.