

March 2, 2023

**ADDENDUM # 2**

**TO PROSPECTIVE PROPOSERS OF DEWATERING CENTRIFUGE REPAIR SERVICE  
REQUEST FOR PROPOSAL (RFP)**

Notice is hereby given that the RFP has been revised as follows:

**ADDENDUM #1**

1. **REPLACE** the Addendum #1 proposal response date “March 6, 2023” with new proposal response date “March 20, 2023.”

**SCHEDULE B.**

2. In Paragraph 1.2.B., “Scope of Work – Annual Overhaul (8,000 hours)”, in item 12, **REMOVE** “Vibration should be less than 8 millimeters per second at 2,600 RPM” and **REPLACE** with “Vibration of bearing housing and machine shall not exceed 8 millimeters per second at 2,600 RPM operating speed. Test run equipment for vibration measurements prior to returning to District.”
3. In Paragraph 1.2.B., “Scope of Work – Annual Overhaul (8000 hours)”, after item 12, **ADD** items 13 and 14 as follows:
  13. Balance scroll and bowl separately to Flottweg Factory specifications (within 5 grams at 750 RPM) using a soft bearing balancing stand.
  14. Vibration readings should be done with the bowl clean and empty.
4. In Paragraph 1.2.C. “Scope of Work – Major Overhaul (40,000 hours),” **DELETE** all paragraphs within part 1.2.C. and **REPLACE** with the following: “1.2.C. – Not Used”


**III. District Procedures, Terms, and Conditions.**

5. In Paragraph H – Bonds, **REPLACE** item 1.a. with the following “A Payment Bond for 100 percent (100%) of the total contract amount.”
6. In Paragraph H – Bonds, **REPLACE** item 1.b. with the following: “A Faithful Performance Bond for 100 percent (100%) of the total contract amount. Bonding requirement – 100% of total contract value.”

**EXHIBIT A – Proposal Form**

7. In the table of quantities and costs on the first page of Exhibit A, **DELETE** the line labeled “SCHEDULE B – Major Overhaul Labor (per unit).”
8. In the table of quantities and costs on the first page of Exhibit A, **DELETE** the line labeled “SCHEDULE B – Major Overhaul Parts, Transit, Tax, All Other Costs (per unit).”

**PROPOSERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE RFP  
RESPONSE FOR CONSIDERATION BY THE DISTRICT.**

  
\_\_\_\_\_  
GLENN D. DOMBECK  
Manager of Wastewater Treatment