



CONSOLIDATED WASTEWATER CONTROL ORDINANCE

Effective September 13, 2024

TITLE I – GENERAL	3
SEC. 1. SHORT TITLE	4
SEC. 2. PURPOSE.....	4
SEC. 3. DEFINITIONS	5
SEC. 4. CONNECTION TO INTERCEPTOR.....	16
SEC. 5. STORMWATER, DRAINAGE, AND GROUNDWATER PROHIBITION.	16
SEC. 6. UNUSUAL CONDITIONS.....	17
TITLE II – REGULATION OF THE WASTEWATER DISCHARGES	18
SEC. 1. PERMISSIBLE DISCHARGES	18
SEC. 2. PROHIBITED DISCHARGES.....	18
SEC. 3. LIMITATIONS ON DISCHARGES.....	21
SEC. 4. FEDERAL PRETREATMENT STANDARDS.....	23
SEC. 5. DISTRICT PRETREATMENT PROGRAM	24



TITLE III – DISCHARGER CLASSIFICATION AND CALCULATION OF WASTEWATER DISPOSAL CHARGES	25
SEC. 1. CLASSIFICATION	25
SEC. 2. CALCULATION OF WASTEWATER DISPOSAL CHARGE.....	25
SEC. 3. DETERMINATION OF WATER USED	27
TITLE IV – WASTEWATER DISCHARGE PERMITS	29
SEC. 1. PERMIT REQUIREMENT	29
SEC. 2. APPLICATION	30
SEC. 3. TERMS AND CONDITIONS OF PERMIT.....	31
SEC. 4. CHANGE OF PERMIT TERMS AND CONDITIONS	33
SEC. 5. TRANSFER OF PERMIT PROHIBITED	34
SEC. 6. TERMINATION	34
TITLE V – ADMINISTRATION.....	35
SEC. 1. AUTHORITY OF DIRECTOR.....	35
SEC. 2. WASTEWATER SOURCE CONTROL REQUIREMENTS.....	35
SEC. 3. SIGNATURE REQUIREMENT	40
SEC. 4. RETENTION OF RECORDS.....	42
SEC. 5. ANALYTICAL AND SAMPLING METHODOLOGY AND PROCEDURES 43	
SEC. 6. PUBLIC NOTIFICATION OF DISCHARGERS FOUND TO BE IN SIGNIFICANT NONCOMPLIANCE	43
SEC. 7. TRADE SECRETS.....	43
SEC. 8. DISTRICT INSPECTION	44
SEC. 9. NEW CONNECTIONS.....	45



TITLE VI – ENFORCEMENT AND PENALTIES.....	46
SEC. 1. DIRECTOR’S ORDERS	46
SEC. 2. DIRECTOR’S ENFORCEMENT REMEDIES AND PENALTIES.....	49
SEC. 3. CRIMINAL PENALTIES.....	53
SEC. 4. CIVIL ENFORCEMENT REMEDIES AND PENALTIES	53
TITLE VII – RESOURCE RECOVERY PROGRAM	55
SEC. 1. PURPOSE.....	55
SEC. 2. REGULATION OF DISCHARGES.....	55
SEC. 3. PERMIT REQUIREMENTS.....	56
SEC. 4. ADMINISTRATION AND ENFORCEMENT.....	56
TITLE VIII – SEVERABILITY	59
TITLE IX – EFFECTIVE DATE.....	59



TITLE I – GENERAL

SECTION 1

SHORT TITLE

This Ordinance shall be known as the “WASTEWATER CONTROL ORDINANCE”.

(Ord. No. 355-11, 7-12-2011)

SECTION 2

PURPOSE

Special District No. 1 of the EAST BAY MUNICIPAL UTILITY DISTRICT was formed and exists under the provisions of the Municipal Utility District Act (Public Utilities Code of the State of California, Division 6) for Wastewater disposal service within its boundaries. Wastewater Disposal Facilities have been constructed for the interception, treatment, and disposal of Wastewater and industrial Wastes originating within its boundaries. The purpose of this Ordinance is to regulate the interception of Wastewater and industrial Wastes and to control Wastewater to provide the maximum public benefit of the Wastewater Disposal Facilities of the District. The regulations shall include provisions for source control in order to monitor and control quantity, quality, and flow of Wastewater and industrial Waste. The regulations shall require charges for use of Wastewater Disposal Facilities of the District which are designed to achieve an equitable recovery of the capital and operating costs of such facilities. The regulations shall include provisions for enforcement and penalties for violations.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



SECTION 3

DEFINITIONS

For the purposes of this Ordinance, unless the context specifically indicates otherwise, the meaning of terms used shall be as follows:

(a) Best Management Practices (BMPs). Schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to implement the prohibitions listed in Title II, Section 2 of this Ordinance. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or Waste disposal, or drainage from raw materials storage.

(b) Board. The Board of Directors of the District.

(c) Business Classification Code. A classification of Dischargers that is determined by the District based upon the principal activity conducted upon, or use of, a parcel of real property or portion thereof. Business Classification Codes are based on the Standard Industrial Classification Manual published by the United States Office of Management and Budget in 1987.

(d) Bypass. The intentional diversion of wastestreams from any portion of a Discharger's treatment facility.

(e) Categorical Industrial User (CIU). A Discharger subject to a Categorical Pretreatment Standard.

(f) Categorical Pretreatment Standards. The regulations containing pollutant Discharge limits that apply to specific categories of Industrial Users, codified in Title 40 of the CFR, Chapter I, Subchapter N, Part 405 *et seq.*

(g) CFR. Code of Federal Regulations.

(h) Chemical Oxygen Demand. Chemical Oxygen Demand is the measure of the oxygen-consuming capacity of inorganic and organic matter present in Wastewater.

(i) Community Sewer. A sewer system owned and operated by a Public Agency within the boundaries of the District which is connected to a District Interceptor and receives Wastewater from the Sewer Lateral of a Discharger.



(j) Contamination. An impairment of the quality of the waters of the state by Waste to a degree which creates a hazard to the public health through poisoning or through the spread of disease. Contamination shall include any equivalent effect resulting from the disposal of Wastewater, whether or not waters of the state are affected.

(k) Director. Director of the Wastewater Department of the East Bay Municipal Utility District, or their designated representative.

(l) Discharger. Any Person who Discharges, permits the Discharge of, or causes the Discharge of Wastewater to a Community Sewer system or District facilities.

(m) District. Special District No. 1 of the East Bay Municipal Utility District.

(n) EPA. The United States Environmental Protection Agency.

(o) Federal Act, Clean Water Act, or Act. The Federal Water Pollution Control Act, also known as the Clean Water Act, as amended (33 U.S.C. § 1251 et seq.).

(p) General Manager. The General Manager of the East Bay Municipal Utility District.

(q) General Permits. Wastewater Discharge Permits for a group of Industrial Users that

- (1) have the same or substantially similar types of operations,
- (2) Discharge the same types of Wastes,
- (3) require the same effluent limitations,
- (4) require the same or similar monitoring, and
- (5) in the opinion of the District are more appropriately controlled under a general control mechanism than under individual control mechanisms.

(r) General Pretreatment Regulations. Any regulations promulgated by EPA in accordance with Sections 307(b) and (c), and 402(b)(8) of the Act (33 U.S.C. § 1317) for the implementation, administration and enforcement of Pretreatment Standards, including the



regulations codified at 40 CFR Part 403.

(s) Indirect Discharge or Discharge. The introduction of Wastewater into a Community Sewer or District facilities.

(t) Industrial User (IU). A source of any Industrial Wastewater from any non-domestic source regulated under Section 307(b), (c) or (d) of the Clean Water Act.

(u) Industrial Wastewater. Includes any nondomestic liquid or semisolid Wastes from any producing, manufacturing, or processing operation of whatever nature.

(v) Interceptor. An intercepting sewer owned and operated by the District that conveys Wastewater from the Community Sewer to the POTW.

(w) Interference. A Discharge which, alone or in conjunction with Discharges from other sources, both:

(1) inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and

(2) therefore is a cause of a violation of any requirement of the POTW's National Pollutant Discharge Elimination System (NPDES) permit (including an increase in the magnitude or duration of a violation) or of the prevention of Sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent state or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including state regulations contained in any state sludge management plan prepared pursuant to subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

(x) Local Limits. Discharge limits and BMPs developed and enforced by the District to implement the general and specific Discharge prohibitions listed in 40 CFR 403.5(a)(1) and (b), as set forth in Title II, Section 3(a) of this Ordinance.

(y) Material Acceptance Permit (MAP). Permit issued by the District under the Resource Recovery Program authorizing the Discharge of hauled Waste of a specific nature, as defined in the permit, at designated receiving stations of the POTW.



(z) Middle Tier Categorical Industrial User. A Categorical Industrial User may be designated by the District as a Middle Tier CIU upon a finding by the Director that it complies with all of the following:

(1) Its Discharge of categorical Wastewater does not exceed any of the following:

(A) 0.01 percent of the design dry weather hydraulic capacity of the POTW, or 5,000 gpd, whichever is smaller;

(B) 0.01 percent of the design dry weather organic treatment capacity of the POTW;

(C) 0.01 percent of the maximum allowable headworks loading for any pollutant listed in the Local Limits;

(2) It has not been in Significant Noncompliance at any time in the past two years; and

(3) It does not have daily flow rates, production levels, or pollutant levels that vary so significantly that decreasing its reporting requirement would result in data that is not representative of conditions occurring during the reporting period.

(aa) National Pretreatment Standard, Pretreatment Standard, or Standard. Any regulation containing pollutant Discharge limits promulgated by the EPA in accordance with Section 307(b) and (c) of the Act, which applies to Industrial Users. This term includes prohibitive Discharge limits established pursuant to 40 CFR 403.5.

(bb) New Source.

(1) A New Source is any building, structure, facility, or installation from which there is or may be a Discharge of pollutants, the construction of which commenced after the publication of proposed Pretreatment Standards which will be applicable to such source if such standards are thereafter promulgated, provided that:

(A) The building, structure, facility or installation is constructed at a site at which no other source is located; or



(B) The building, structure, facility or installation totally replaces the process or production equipment that causes the Discharge of pollutants at an existing source; or

(C) The production or Wastewater generating processes of the building, structure, facility or installation are substantially independent of an existing source at the same site. In determining whether these are substantially independent, factors such as the extent to which the new facility is integrated with the existing plant, and the extent to which the new facility is engaged in the same general type of activity as the existing source should be considered.

(2) Construction on a site at which an existing source is located results in a modification rather than a New Source if the construction does not create a new building, structure, facility or installation meeting the criteria of paragraphs (bb)(1)(B) or (bb)(1)(C) of this Section, but otherwise alters, replaces, or adds to existing process or production equipment.

(3) Construction of a New Source has “commenced” if the owner or operator has:

(A) Begun, or caused to begin as part of a continuous onsite construction program:

(i) Any placement, assembly, or installation of facilities or equipment; or

(ii) Significant site preparation work including clearing, excavation, or removal of existing buildings, structures, or facilities which is necessary for the placement, assembly, or installation of new source facilities or equipment; or

(B) Entered into a binding contractual obligation for the purchase of facilities or equipment which are intended to be used in its operation within a reasonable time. Options to purchase or contracts which can be terminated or modified without substantial loss, and contracts for feasibility, engineering, and design studies do not constitute a contractual obligation under this paragraph.



(cc) Non-Significant Categorical Industrial User (NSCIU). A Categorical Industrial User may be designated by the District as a Non-Significant Categorical Industrial User, subject to annual reevaluation by the District, upon a finding by the Director that it meets the following criteria:

(1) Never Discharges more than 100 gallons per day of total categorical Wastewater (excluding sanitary, non-contact cooling and boiler blowdown Wastewater, unless specifically included in the applicable Categorical Pretreatment Standard);

(2) Has consistently complied with all applicable Categorical Pretreatment Standards and Requirements;

(3) Annually submits the certification statement required in 40 CFR 403.12(q); and

(4) Never Discharges any untreated concentrated Wastewater.

(dd) Nuisance. A Discharge of Wastewater in violation of District regulations or Orders, or which is or could be harmful to or unreasonably affect the Wastewater Disposal Facilities of the District, or which impairs or unreasonably affects the operation and maintenance of such facilities, or which violates quantity, quality, or flow standards adopted by the District, and all Wastewater Discharges which unreasonably affect the quality of the District's treatment plant effluent in such a manner that Receiving Water Quality Requirements established by law cannot be met by the District.

(ee) Order. For purposes of this Ordinance, an Order is either:

(1) A mechanism to control the contribution to the POTW by each Discharger or Resource Recovery Program participant to ensure compliance with applicable Pretreatment Standards and other Wastewater Discharge requirements.

(2) An Order issued under Title VI of this Ordinance for purposes of enforcement.

(ff) Ordinance. This Wastewater Control Ordinance, as amended.

(gg) Pass Through. A Discharge which exits the POTW into waters of the State in quantities or concentrations which, alone or in conjunction with a Discharge or



Discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).

(hh) Person. Any individual, partnership, firm, association, corporation, or Public Agency, including the State of California and the United States of America.

(ii) Pollution. An alteration of the quality of the waters of the state by Waste to a degree which unreasonably affects (1) such waters for beneficial use or (2) facilities which serve such beneficial uses.

(jj) Premises. A parcel of real property, or portion thereof, including any improvements thereon, which is determined by the District to be a single unit for purposes of receiving, using, and paying for Wastewater disposal service. In making this determination, the District shall take into consideration such factors as whether the unit could reasonably be subdivided, number and location of Sewer Laterals, and whether the unit is being used for a single activity and, if not, what is the principal activity for Wastewater disposal services, and whether the unit is divided by a public or a private street, but in any case the District determination shall be final.

(kk) Pretreatment Requirement or Requirement. Any substantive or procedural pretreatment requirement other than a National Pretreatment Standard.

(ll) Process Wastewater. Any water which, during manufacturing or processing, comes into direct contact with, or results from the production or use of any raw material, intermediate product, finished product, byproduct, or Waste product.

(mm) Public Agency. A city or a sanitary district or other public entity located within the boundaries of the District.

(nn) Publicly Owned Treatment Works (POTW). A treatment works as defined by Section 212 of the Clean Water Act, which is owned by the District. This definition includes any District-owned devices and systems used in the storage, treatment, recycling and reclamation of municipal Sewage or industrial Wastes of a liquid nature. It also includes District-owned sewers, pipes, pump stations, and other facilities that convey Wastewater to that portion of the POTW which is designed to provide treatment (including recycling and reclamation) of municipal Sewage and industrial Waste. Where indicated by context, "POTW" may also refer to the District itself.

(oo) Receiving Water Quality Requirements. Requirements for the District's



treatment plant effluent established by law or by State or Federal regulatory agencies for the protection of receiving water quality. “Requirements” shall include effluent limitations, and Waste Discharge standards, requirements, limitations, or prohibitions which may be established or adopted from time to time by State or Federal laws or regulatory agencies.

(pp) Representative Data. Data obtained through analysis of Representative Samples using approved analytical methods and procedures.

(qq) Representative Sample. Samples of Discharges that are obtained using approved sampling methods, that are representative of the quantity and quality of the Discharge, and the conditions occurring during the time the Discharge was sampled or measured.

(rr) Severe Property Damage. Substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a Bypass. Severe property damage does not mean economic loss caused by delays in production.

(ss) Sewage. The water-borne Wastes derived from human habitation and use of buildings for residential, business, commercial, institutional, and industrial purposes.

(tt) Sewer Lateral. The sewer pipe that conveys Wastewater from a Discharger at a residence, commercial, industrial, or institutional building, or other structure, to a Community Sewer.

(uu) Significant Industrial User.

(1) A Categorical Industrial User other than a Non-Significant Categorical Industrial User; or

(2) A User that:

(A) Discharges an average of twenty-five thousand (25,000) gallons per day or more of process Wastewater to the POTW (excluding sanitary, noncontact cooling, and boiler blowdown Wastewater);

(B) Contributes a process wastestream which makes up five (5) percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or



(C) Is designated as such by the District on the basis that it has a reasonable potential for adversely affecting the POTW's operation or for violating any Pretreatment Standard or Requirement.

(3) Upon a finding that a User meeting the criteria in Subsection (2) above has no reasonable potential for adversely affecting the POTW's operation or for violating any Pretreatment Standard or Requirement, the District may at any time, on its own initiative or in response to a petition received from a User, determine that such User should not be considered a Significant Industrial User.

(vv) Significant Noncompliance. A Significant Industrial User (or any IU which violates paragraphs 3, 4, or 8 below) is in Significant Noncompliance with applicable Pretreatment Requirements if any violation meets one or more of the following criteria:

(1) Chronic violations of Wastewater discharge limits, defined here as those in which sixty-six percent or more of all of the measurements taken during a six month period exceed (by any magnitude) a numeric Pretreatment Standard or Requirement, including instantaneous limits, as defined by 40 CFR 403.3(l).

(2) Technical Review Criteria (TRC) violations, defined here as those in which thirty-three percent or more of all of the measurements for each pollutant parameter taken during a six-month period are equal to or exceed the product of the numeric Pretreatment Standard or Requirement including instantaneous limits, as defined by 40 CFR 403.3(l) multiplied by the applicable TRC (TRC = 1.4 for BOD, TSS, fats, oil and grease and 1.2 for all other pollutants except pH).

(3) Any other violation of a Pretreatment Standard or Requirement as defined by 40 CFR 403.3(l) (daily maximum, long-term average, instantaneous limit, or narrative standard) that the District determines has caused, alone or in combination with other Discharges, Interference or Pass Through (including endangering the health of POTW personnel or the general public).

(4) Any Discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment or has resulted in the POTW's exercise of its emergency authority to halt or prevent such a Discharge.

(5) Failure to meet, within 90 days after the due date, a compliance schedule milestone contained in a local control mechanism or enforcement Order for starting construction, completing construction or attaining final compliance.



(6) Failure to provide, within 45 days after the due date, required reports such as baseline monitoring reports, 90-day compliance reports, periodic self-monitoring reports and reports on compliance with compliance schedules.

(7) Failure to accurately report noncompliance.

(8) Any other violation or group of violations which the District determines will adversely affect the operation or implementation of the local pretreatment program.

(ww) Slug Load or Slug Discharge. Any Discharge at a flow rate or concentration, which could cause a violation of the prohibited Discharge standards in Title II, Section 2 of this Ordinance. A Slug Discharge is any Discharge of a non-routine, episodic nature, including but not limited to an accidental spill or non-customary batch Discharge which has a reasonable potential to cause Interference or Pass Through, or in any other way violate the District's regulations, Local Limits or permit conditions.

(xx) Suspended Solids. The concentration of nonfilterable residue dried at 103° to 105°C on a filter in conformance with the District's approved method.

(yy) User. Same meaning as “Discharger” and is used interchangeably with that term.

(zz) Unmetered Water. Water that is not supplied by East Bay Municipal Utility District through an East Bay Municipal Utility District meter, including but not limited to stormwater, drainage water, groundwater, or Bay water.

(aaa) Waste. Includes Sewage and any and all other Waste substances, liquid, solid, gaseous, or radioactive, associated with human habitation, or of human or animal origin, or from any producing, manufacturing, or processing operation of whatever nature.

(bbb) Wastewater. All Sewage, Industrial Wastewater, and other Wastes and waters, whether treated or untreated, Discharged for treatment in Wastewater Disposal Facilities of the District.

(ccc) Wastewater Capacity Fee. A charge to each new customer, or existing customer who increases their demand for capacity for Wastewater treatment measured by flow and strength, which reasonably reflects the District cost for providing Wastewater treatment capacity.



(ddd) Wastewater Discharge Permit. A written document that contains general and specific requirements governing onsite management, pretreatment, and Discharge of Wastewater to the Community Sewer. A Wastewater Discharge Permit is issued by the Director and grants revocable permission to Discharge Wastewater to the Community Sewer.

(eee) Wastewater Disposal Facilities. Intercepting sewers, Wastewater treatment works, pumping plants, outfall sewers, and other facilities and appurtenances constructed, operated, and maintained by a special district created for Wastewater disposal purposes. As used in this Ordinance, unless the context specifically indicates otherwise, “District Facilities” shall mean Wastewater Disposal Facilities of the District.

(fff) Wastewater Strength. A measurement of the concentration of the constituents in Wastewater requiring treatment, including Suspended Solids and organic loading (measured as Chemical Oxygen Demand).

(ggg) Zero Discharger. Persons engaged in an industrial process that poses a risk of Discharge, as determined by the Director, and who the Director has further determined should be subjected to permit requirements, but who are not permitted to Discharge to the Community Sewer.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)



SECTION 4

CONNECTION TO INTERCEPTOR

The District will not permit direct connections of or accept direct contributions of Wastewater from sewers other than Community Sewers. Before any connection of a Community Sewer is made to an Interceptor, an application signed by the Public Agency owning the Community Sewer to be connected shall be filed with the District. The application shall be in a form approved and supplied by the District, and shall contain such information and data as may be required from time to time by the District. The connecting of Community Sewers will be performed by the Public Agency at its expense in accordance with District requirements and subject to approval and inspection by the District.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 5

STORMWATER, DRAINAGE, GROUNDWATER, AND BAY WATER PROHIBITION

(a) The District's Wastewater Disposal Facilities are not intended to dispose of waters that are acceptable for Discharge to storm sewers or to receiving waters of the State. No User shall Discharge stormwater, drainage, groundwater, or Bay water to the Community Sewer unless expressly authorized by the Director. In the event of the Discharge of such waters from a Community Sewer into an Interceptor, the District may determine the amount of such Discharge and charge the owner of the Community Sewer the cost to the District of disposing and treating such water.

(b) The Director may approve the Discharge of stormwater, drainage, groundwater, or Bay water into the District's Wastewater Disposal Facilities on such terms and conditions as the Director may require. No such Discharge will be approved unless the Director finds that:

- (1) sufficient capacity exists to convey and treat the additional flows;
- and
- (2) the Discharge will not adversely affect the POTW or its ability to comply with all applicable legal requirements.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)



SECTION 6

UNUSUAL CONDITIONS

Notwithstanding any provision of this Ordinance to the contrary, the District and any Discharger or Public Agency may enter into an agreement where unusual conditions compel special terms and conditions and charges for the interception, treatment, and disposal of the Wastewater by the District. However, this Section does not authorize the waiver of Federal or State standards or requirements.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



TITLE II – REGULATION OF THE WASTEWATER DISCHARGES

SECTION 1

PERMISSIBLE DISCHARGES

Wastewater may be Discharged into Community Sewers for interception, treatment, and disposal by the District provided that such Wastewater does not contain substances prohibited by this Ordinance or exceed limitations of Wastewater concentration as set forth in this Ordinance; and provided further that the Discharger pays all District Wastewater disposal charges and is in compliance with all terms of this Ordinance, including permit provisions if applicable.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 2

PROHIBITED DISCHARGES

(a) General Prohibition. No Person shall Discharge Wastewater into a Community Sewer which will result in Contamination, Pollution, or a Nuisance.

(b) Prohibited Effects. No Person shall Discharge Wastewater into a Community Sewer if it contains substances or has characteristics which, either alone or by interaction with other Wastewaters, cause or threaten to cause:

- (1) Damage to District facilities.
- (2) Interference with or impairment of the operation or maintenance of District facilities.
- (3) Obstruction of flow in sewers or Interceptors caused by solid or viscous materials.
- (4) Danger to life or safety of any Person.
- (5) Interference with, or overloading of, treatment or disposal processes.



(6) Flammable or explosive conditions at or near District facilities.

(7) Wastewater or any other by-products of the treatment process to be unsuitable for reclamation and reuse, or interfere with any processes for reclamation or reuse.

(8) Noxious or malodorous gases or odors at or near District facilities.

(9) Discoloration or any other condition in the quality of the District's treatment plant effluent in such a manner that Receiving Water Quality Requirements established by law cannot be met by the District.

(10) Conditions at or near District facilities which violate any statute or any rule, regulation, or ordinance of any Public Agency or State or Federal regulatory body, including the general prohibitions contained in Federal General Pretreatment Regulations.

(11) The presence of toxic gases, fumes, or vapors in quantities injurious to the health and safety of District personnel.

(12) Pass Through of the District's treatment plant, causing a violation of any requirement of the District's NPDES permit.

(c) Prohibited Substances. No Person shall Discharge the following to a Community Sewer:

(1) Wastewater which creates a fire or explosion hazard including, but not limited to, Discharges with a closed cup flashpoint of less than 140°F (60°C) using the test methods specified in 40 CFR 261.21.

(2) Garbage, except ground food scraps from residential and commercial Premises where food is prepared and consumed.

(3) Wastewater which is subject to a Wastewater Discharge Permit except in compliance with such permit.

(d) Prohibited Locations. No Person shall Discharge any Waste or Wastewater directly into a maintenance hole or other opening in a Community Sewer other than through Sewer Laterals approved by the Public Agency owning the system; provided that a Public



Agency may Discharge Wastewater directly into its system for sewer construction or maintenance and the Director may grant permission for direct Discharges to the Community Sewer, upon written application, at locations approved by the Public Agency and with payment of applicable Wastewater disposal charges to the District. No Person shall Discharge any Waste, Wastewater, or any other material directly into District facilities, including Interceptor maintenance holes, unless authorized by the Director.

(e) Prohibition on Use of Dilution. Except where expressly authorized to do so by an applicable Pretreatment Standard or Requirement, no User shall increase the use of process water, or in any other way attempt to dilute a Discharge as a partial or complete substitute for adequate pretreatment to achieve compliance with a Pretreatment Standard, Requirement or Discharge limitation. The District may impose mass limitations on the Users which are using dilution to meet applicable Pretreatment Standards or Requirements, or in other cases where the imposition of mass limitations is appropriate.

(f) Prohibition on Slug Discharges. No User shall Discharge any pollutant, including oxygen-demanding pollutants, at a flow rate and/or pollutant concentration which causes or threatens to cause Interference with the Wastewater treatment process. For the purposes of this Section, any Discharge at a flow rate or concentration which could cause a violation of the prohibited Discharge standards or limitations in Title II, Sections 2 and 3 of this ordinance shall be deemed a Slug Discharge.

(g) Bypass Prohibited.

(1) Bypass of pretreatment equipment and/or Discharge points is prohibited and the District may take enforcement action against any User for Bypass unless:

(i) Bypass was unavoidable to prevent loss of life, personal injury, or Severe Property Damage;

(ii) there were no feasible alternatives to the Bypass, as described in 40 CFR 403.17(d) and the Industrial User submits the notifications required in 40 CFR 403.17(c).

(2) The District may approve an anticipated Bypass, after considering its adverse effects, if the District determines that it will meet the conditions specified in part (g)(1) of this prohibition.



(h) Discharge of Petroleum or Mineral Oil Causing Pass Through or Interference Prohibited. Notwithstanding the provisions of Section 3(a), no User may Discharge petroleum oil, non-biodegradable cutting oil or other products of mineral origin in any amount that causes Interference or Pass Through.

(i) Discharge of Trucked or Hauled Wastes Prohibited. No User shall Discharge any trucked or otherwise hauled Wastes to the Community Sewer or to any District facilities unless a Material Acceptance Permit has been issued by the District.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 3

LIMITATIONS ON DISCHARGES

(a) Local Limits. No Person shall Discharge Wastewater from a Sewer Lateral into a Community Sewer if the concentration of any of the following constituents in the Wastewater exceeds the following limitations:



Arsenic	2	mg/L
Cadmium	1	mg/L
Chromium (total)	2	mg/L
Copper	5	mg/L
Cyanide	5	mg/L
Iron	100	mg/L
Lead	2	mg/L
Mercury	0.05	mg/L
Nickel	5	mg/L
Oil and Grease (animal/vegetable)	300	mg/L
Oil and Grease (mineral)	100	mg/L
pH	not less than 5.5	S.U.
Phenolic compounds	100	mg/L
Silver	1	mg/L
Temperature	150 ⁽¹⁾	°F
Total Toxic Organics (TTOs) ⁽²⁾	2.1	mg/L
Zinc	5	mg/L

- (1) 150°F (65.5°C), or any thermal discharge which as a result of temperature and/or volume causes the influent of the wastewater treatment plant to exceed 104°F (40°C).
- (2) TTO is the summation of compounds defined as “TTO” in 40 CFR 413.02(i), excluding 2,3,7,8-Tetrachlorodibenzo-p-dioxin (TCDD) - “dioxin”

(b) Additional Wastewater Concentration Limits. Wastewater concentration limits for constituents not listed in Section 3(a) may be established in a Wastewater Discharge Permit based on available treatment technology, existing Wastewater conditions in the District's facilities or other factors as determined by the Director. The Director may



also establish Wastewater concentration limits in the Wastewater Discharge Permits at locations within a Premises whenever non-process Wastewater may dilute the Wastewater discharging from Sewer Laterals.

(c) Best Management Practices. The District may require BMPs as an alternative to numeric limits that are developed to protect the POTW, water quality, and Sewage sludge.

(d) Quantity and Rate of Flow Limits. No Person shall Discharge Wastewater into a Community Sewer in quantities or at rates of flow which may have an adverse or harmful effect on or overload District facilities or cause excessive or additional District treatment costs. The Director may establish mass Discharge limits in Wastewater Discharge Permits to control the quantity and rate of flow of Wastewater Discharges.

(e) Radioactive Limits. No Person shall Discharge or cause to be Discharged any radioactive Wastewater into a Community Sewer except when the Person is authorized to use radioactive material by the Nuclear Regulatory Commission or other governmental agency empowered to regulate the use of radioactive materials and when the Wastewater is Discharged in strict conformity with current Nuclear Regulatory Commission regulations and recommendations for safe, disposal and in compliance with all rules and regulations of State and local regulatory agencies.

(f) Deny or Condition New or Increased Contributions. The Director may deny or condition new or increased contributions of pollutants, or changes in the nature of pollutants, to the District's Wastewater treatment facility by Industrial Users where such contributions do not meet applicable Pretreatment Standards and Requirements or where such contributions would cause the District to violate its NPDES permit.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 4

FEDERAL PRETREATMENT STANDARDS

The General Pretreatment Regulations and Categorical Pretreatment Standards are hereby incorporated into this Ordinance and, if more stringent than limitations imposed under the Ordinance for Dischargers, shall supersede the limitations imposed under this Ordinance. The Director shall notify all affected Dischargers of the applicable standards and other requirements. Effluent limitations promulgated under the authority of the Clean



Water Act shall apply in any instance where they are more stringent than those in this Ordinance.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 5

DISTRICT PRETREATMENT PROGRAM

The Director shall implement a pretreatment program in accordance with General Pretreatment Regulations adopted by EPA and in accordance with this Ordinance.

(Ord. No. 355-11, 7-12-2011)



TITLE III – DISCHARGER CLASSIFICATION AND CALCULATION OF WASTEWATER DISPOSAL CHARGES

SECTION 1

CLASSIFICATION

All Dischargers shall be classified for Wastewater disposal purposes in accordance with the principal activity conducted upon the Premises, or in accordance with the use of the Premises, for purposes of Wastewater treatment, as determined by the District in case multiple tenants or activities are on the Premises. The purpose of classification is to facilitate the regulation of Wastewater Dischargers based on quality, quantity and flow, to provide an effective means of industrial Waste source control, and to establish a system of Wastewater disposal service charges, which will insure an equitable recovery of District capital and operating costs.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 2

CALCULATION OF WASTEWATER DISPOSAL CHARGE

All Dischargers shall pay a use charge for District Wastewater disposal services. The charges will reflect the quantity, quality, and flow of the Dischargers' Wastewater and will be based on District capital and operating costs to intercept and treat Wastewater. All Dischargers shall also pay all other charges, fees, tolls, rentals or taxes as from time to time established or adopted by the District. Flat charges, unit charges and classification charges shall be established from time to time and set forth in a schedule of rates and charges. Unit charges will be established for each element of Wastewater Strength which incurs District costs of interception, treatment and disposal. The total Wastewater disposal charge for each Discharger shall be calculated as set forth herein:

(a) Dischargers from Residential Premises with Four or Less Dwelling Units. Dischargers from residential Premises with four or less dwelling units shall pay a total Wastewater disposal charge, regardless of the source of water, which shall be the sum of a uniform flat monthly charge per dwelling unit for Wastewater Strength and the unit charge



for volume multiplied by the volume of water used, subject to a maximum volume established by the District from time to time and set forth in a schedule of rates and charges.

(b) Dischargers from Residential Premises with Five or More Dwelling Units and Dischargers from Nonresidential Premises including Permitted Dischargers. Dischargers of Wastewater from residential Premises with five or more dwelling units, and Dischargers from nonresidential Premises, including Dischargers who have obtained a Wastewater Discharge Permit, will be assigned a Business Classification Code depending on the principal activity conducted on the Premises or the use of the Premises for purposes of Wastewater treatment, as determined by the District in case multiple tenants or activities are on the Premises. All Dischargers conducting the same principal activity will receive the same Business Classification Code. The Director shall determine the typical Wastewater Strength for each Business Classification Code, and each Discharger within that classification will be assumed, for Wastewater disposal charge purposes, to have the same typical Wastewater Strength. The Director shall also subclassify within each Business Classification Code those Dischargers who Discharge primarily segregated domestic Wastes or Wastes from sanitary conveniences. A classification charge shall be established by the District for each Business Classification Code and subclassification, which will be based on unit charges for the elements of Wastewater Strength, as applied to the typical Wastewater Strength of the particular classification. The Wastewater disposal charge applied to a Discharger in this class will be calculated by multiplying the classification charge by the volume of water used by the Discharger.

(c) Permitted Dischargers with Unique Strength. Dischargers whose average Wastewater Strength cannot be established on a business classification basis, or whose Wastewater Strength exceeds the normal range of Wastewater Strength for the Business Classification Code to which the Discharger is assigned, shall be required to obtain a permit and shall pay a Wastewater disposal charge calculated as the sum of the products of the following: The unit charge for each element of Wastewater Strength multiplied by the average concentration of each element set forth in the permit multiplied by the volume of water used; and the unit charge for volume multiplied by the volume of water used as determined herein. The Wastewater disposal charge for these permitted Dischargers, including both Wastewater Strength and water use, shall be calculated by an apportionment by the Director of strength and use to each Sewer Lateral at the Discharger's Premises. Dischargers requiring permits solely for flow estimation shall pay a Wastewater disposal charge calculated by multiplying the classification charge by the volume of water determined by the estimation. In addition to a Wastewater disposal charge, the permitted Discharger shall pay all applicable District permit charges. All Dischargers required to obtain a permit shall pay a Wastewater disposal charge in accordance with their Business Classification Code until



a permit is issued.

(d) Capacity fee. A Wastewater Capacity Fee shall be paid as established from time to time by the District and which reflects the reasonable costs of providing Wastewater treatment capacity. The Wastewater Capacity Fee shall be payable prior to the time a new Discharger commences a use of the Community Sewer. The District will calculate the Wastewater Capacity Fee based on the best available estimated information for the proposed Discharger, based on the flow, strength, and other pertinent design information at the time the new Discharger applies for the District's service. Once the new Discharger is fully established, within 24 months from commencement of Discharge, the District may review the actual flow and/or strength to verify the estimated demand for Wastewater treatment capacity. If the review indicates that the actual measured flow or strength of the Discharge is greater than the initially estimated information, the District will collect an additional Wastewater Capacity Fee. The Wastewater Capacity Fee was made effective September 11, 1984 and the Wastewater Capacity Fee shall apply to all Dischargers who increased demand for Wastewater treatment capacity on or after July 1, 1984.

An existing Discharger shall pay a capacity fee when the District determines that the Discharger has increased their demand for Wastewater treatment capacity. An increased demand for Wastewater treatment capacity may also be reviewed when an existing Discharger significantly increases their Wastewater treatment capacity demand or changes the nature of their operation. An increased demand for Wastewater treatment capacity can occur even if estimating parameters (e.g., square footage, fixtures) for the Discharger may not have changed.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 3

DETERMINATION OF WATER USED

The applicable volume of water upon which Wastewater disposal charges shall be based will be determined as follows:

(a) Water Discharged to Community Sewer. For Premises where no portion of the water received from any source is consumed in the principal activity of the Discharger or



is removed from the Premises by means other than Community Sewers, the Wastewater disposal charge shall be applied against the total amount of water, from all sources, discharged to the Community Sewer. The amount of East Bay Municipal Utility District water received will be determined by registration on an East Bay Municipal Utility District meter. The amount of water used from other sources will be determined by means of a meter installed at the expense of the Discharger and approved by the District or by an estimate prepared by the District, after the Discharger obtains a permit in accordance with this Ordinance. The Discharger shall report to the District the sources of all water used at their Premises other than that supplied by the East Bay Municipal Utility District and shall notify the District of any changes in such sources.

(b) Water Not Discharged to Community Sewer. For Premises where a portion of the water received from any source does not flow into Community Sewers, because of the principal activity of the Discharger or removal by other means, the charge for Wastewater disposal service will be applied against the volume of water discharging from such Premises into Community Sewers. Written notification and proof of the diversion of water must be provided by the Discharger if they are to avoid application of the Wastewater disposal charge against the total amount of water used from all sources. They may be required to install a meter, of a type and at a location approved by the District and at their own expense, to determine the quantity of water flowing into Community Sewers. However, where it is impractical to install meters and where a significant amount of the metered water consumption is not being Discharged to a Community Sewer, then the charge for Wastewater disposal service may be based upon an estimate prepared by the District, after the Discharger obtains a permit in accordance with this Ordinance.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



TITLE IV – WASTEWATER DISCHARGE PERMITS

SECTION 1

PERMIT REQUIREMENT

All Dischargers whose Wastewater requires special regulation or contains industrial Wastes requiring source control shall secure a Wastewater Discharge Permit. No such Discharger shall connect, Discharge, cause, allow or permit any Discharge to the Community Sewer, either directly or indirectly, except in accordance with a Wastewater Discharge Permit issued by the Director.

(a) Mandatory Permits. All Dischargers in the following categories must obtain a Wastewater Discharge Permit in accordance with this Title.

- (1) Significant Industrial Users, as defined in Title I.
- (2) Industrial Users not otherwise specified in this Section who are determined by the Director to warrant a control mechanism for purposes of preventing Pass Through or Interference, to protect the water quality of the San Francisco Bay, to protect worker health or safety, to facilitate sludge management or disposal, or to protect against damage to the POTW, which may include Non-Significant Categorical Industrial Users, as defined in Title I, and Zero Dischargers.
- (3) Dischargers determined by the Director to require a permit to establish Wastewater disposal charges based on flow and Wastewater Strength. These may include:
 - (i) Dischargers whose average Wastewater Strength cannot be established on a business classification basis,
 - (ii) Dischargers whose Wastewater Strength exceeds the normal range of Wastewater Strength for the Business Classification Code to which the Discharger is assigned.
 - (iii) Dischargers disposing of Unmetered Water, to whom the District may issue the following types of permits:



- A. Limited-Term Permits. Permits for Users who request a permit for temporary Discharges of Unmetered Water during a specified term;
- B. Groundwater Permits. Permits for Users who request a permit to Discharge groundwater on an ongoing basis; or
- C. Industrial User Permits. Permits for any other User that requests a permit to Discharge Unmetered Water.

(b) Estimation Permits. Estimation Permits may be issued to a Discharger which demonstrates a significant amount of the Discharger's metered water consumption is not being Discharged to a Community Sewer. For the purposes of this Ordinance, any diversion from the Community Sewer shown to be more than 20 percent of the metered water consumption shall qualify for an Estimation Permit. Other Dischargers who can demonstrate a significant diversion may request a permit, which shall be subject to approval by the Director.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 2

APPLICATION

Dischargers seeking a Wastewater Discharge Permit shall complete and file with the Director a District application form, accompanied by any applicable District fees. New Dischargers shall file applications 60 days prior to commencement of Discharges, unless such time is extended for good cause. The application may require the following information:

- (a) name, site address, and mailing address (if different than site address) of business;
- (b) estimated Wastewater Strength;
- (c) estimated concentration of each constituent for which a Local Limit has been established as stated in Title II Section 3 as applicable, and any other constituents that could result in Prohibited Discharges as described in Title II Section 2.
- (d) environmental control permits held by or for the facility;



- (e) estimated Wastewater flow, average and peak Wastewater Discharge flow for each Sewer Lateral;
- (f) locations of Sewer Laterals, sampling points, and pretreatment facilities;
- (g) description of activity, facilities, and plant process on the Premises, including raw materials, processes and types of materials which are or could be Discharged;
- (h) total product produced, by type;
- (i) number and type of employees;
- (j) days and hours of operation and days and hours of Discharge;
- (k) slug control plan which outlines Discharge practices (including non-routine batch Discharges), describes stored chemicals, and contains procedures both to notify the District immediately of Slug Discharges and to prevent adverse impacts from any accidental spill; and
- (l) any other information the Director shall deem necessary to evaluate the permit application.

The Director shall evaluate the application in light of this Ordinance’s stated purposes and approve, conditionally approve, or deny the application as appropriate under the circumstances. Any Discharger aggrieved by the Director’s decision to deny an application may appeal that decision by utilizing the procedures described in Title VI, Section 2(e) of this Ordinance.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 3

TERMS AND CONDITIONS OF PERMIT

(a) Terms. All Wastewater Discharge Permits shall require the permittee to comply with all provisions of this Ordinance and all rates and charges established by the District. A Wastewater Discharge Permit may contain terms, conditions or other provisions that are more stringent than the requirements of this Ordinance. A Discharger must comply with all Wastewater Discharge Permit terms and conditions, and failure to do so is a



violation of this Ordinance. A permit issued to a Significant Industrial User shall be valid for a specified time period, not to exceed five years or the maximum time allowed by law. The Director may renew a permit issued to a Significant Industrial User for any period not to exceed five years or the maximum time allowed by law. The period of validity for all other permits shall be as determined by the Director, and may include permits with no expiration date, provided that the Director may revise or terminate any permit at any time in the manner provided by this Ordinance. Permit renewal applications shall be submitted to the District at least 60 days before the permit expires. A permit issued to a Significant Industrial User shall require the permittee to notify the District immediately of any changes at its facility affecting the potential for a Slug Discharge.

(b) Conditions. Wastewater Discharge Permits may contain any or all of the following conditions:

- (1) Effluent limits, including Categorical Pretreatment Standards and Local Limits.
- (2) Limits on rate and time of Discharge or requirements for flow regulation and equalization.
- (3) Requirements for inspection and sampling facilities, including District access to such facilities.
- (4) Monitoring program which may include: Sampling locations; frequency and method of sampling; number, types and standard of tests; and establishing a reporting schedule. The Discharger assigned a monitoring program in conformance with this Ordinance shall pay all applicable District charges.
- (5) Submission of technical reports or Discharge reports, including, but not limited to, reports described in Title V, Section 2 of this Ordinance, or any report required by 40 CFR 403.12.
- (6) Maintenance of records relating to Wastewater Discharges, as specified by the Director, and affording District access thereto.
- (7) A statement of applicable penalties for violation of Pretreatment Standards and Requirements, and any applicable compliance schedule.
- (8) Requirements for the development and implementation of Pollution



prevention plans to reduce the amount of pollutants Discharged to the District's treatment plant.

(9) Notification requirements including immediate notification of any changes that affect the potential for a Slug Discharge.

(10) Requirements for the development and implementation of spill control plans or other special conditions including management practices necessary to adequately prevent accidental, unanticipated, or nonroutine Discharges.

(11) Installation of technology, as specified by the Director.

(12) Requirements to implement Best Management Practices.

(13) Other conditions as deemed appropriate by the Director to ensure compliance with this Ordinance or the terms and conditions of the Wastewater Discharge Permit.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 4

CHANGE OF PERMIT TERMS AND CONDITIONS

Once issued, the Director may change the terms and conditions of a Wastewater Discharge Permit, including changing the limits on Wastewater constituents, from time to time as circumstances may require. The District shall allow a Discharger reasonable time to comply with any District required changes in the permit except that a change that affects billing shall immediately affect calculation of the Wastewater disposal charge.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



SECTION 5

TRANSFER OF PERMIT

A Wastewater Discharge Permit shall not be assigned or transferred without prior notice to and approval from the Director.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 6

TERMINATION AND MODIFICATION FOR VIOLATIONS

The Director may terminate or modify any Wastewater Discharge Permit for violation of the terms and conditions of the permit or the provisions of this Ordinance. Any Person aggrieved by the Director's decision to terminate or modify a Wastewater Discharge Permit based on such violations may appeal that decision using the procedures described in Title VI, Section (2)(f). A Discharger whose permit has been terminated based on such violations, and who desires to resume Discharging, shall apply for a new permit within 30 days of issuance of the notice of termination.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



TITLE V – ADMINISTRATION

SECTION 1

AUTHORITY OF DIRECTOR

The Director is charged with responsibility for District's Wastewater control program and the administration and enforcement of the provisions of this Ordinance.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 2

WASTEWATER SOURCE CONTROL REQUIREMENTS

In order to effectively administer and enforce the provisions of these regulations, the Director may require any Discharger to comply with any or all the following requirements:

(a) Discharge Reports. The Director may require Discharge reports, including but not limited to questionnaires, technical reports, sampling reports, and test analyses, and periodic reports of Wastewater Discharge. When a report filed by a Person pursuant to this Section is not adequate in the judgment of the Director, the Director may require such Person to supply such additional information as the Director deems necessary. The Discharge report may include, but not be limited to, nature of the process, volume and rates of Wastewater flow, elements, constituents, and characteristics of the Wastewater, together with any information required in an application for Wastewater Discharge Permit.

(b) Baseline Monitoring Report. Each Categorical Industrial User shall submit a baseline monitoring report (BMR). The requirements for a BMR, as described in 40 CFR 403.12(b) are hereby incorporated into this Ordinance. A BMR, if required, shall be reviewed by an authorized representative of the User, and certified to by a qualified professional, indicating whether Pretreatment Standards are being met on a consistent basis, and if not, whether additional operation and maintenance and/or additional pretreatment is required for the User to meet the Pretreatment Standards and Requirements.

(c) Periodic Report of Continued Compliance.



(1) Each Categorical Industrial User, other than a Non-Significant Categorical Industrial User or Middle Tier Categorical Industrial User, shall submit to the District twice per year a report describing the nature and concentration of the pollutants which are regulated by the Categorical Pretreatment Standards and Local Limits applicable to the CIU. The User's report must be based on sampling and analysis performed during the six-month reporting period and in accordance with the techniques described in 40 CFR Part 136 and amendments thereto. At the District's discretion, this sampling and analysis may be performed by the District. If a Categorical Pretreatment Standard requires compliance with a Best Management Practice or Pollution prevention alternative, the User must submit all documentation necessary for the District to determine the User's compliance status. The report shall include the average and maximum daily flows. The District may determine during which months the CIU shall submit these reports.

(2) Each Middle Tier Categorical Industrial User must submit to the District once per year a report describing the nature and concentration of the pollutants which are regulated by the Categorical Pretreatment Standards and Local Limits applicable to the CIU. The User's report must be based on sampling and analysis performed during the six-month reporting period and in accordance with the techniques described in 40 CFR Part 136 and amendments thereto. At the District's discretion, this sampling and analysis may be performed by the District. If a Categorical Pretreatment Standard requires compliance with a Best Management Practice or Pollution prevention alternative, the User must submit all documentation necessary for the District to determine the User's compliance status. The report shall include the average and maximum daily flows. The User must immediately notify the District of any changes at its facility causing it to no longer meet all conditions required for the District to designate it as a Middle Tier Categorical Industrial User and, upon giving such notification, must immediately begin submitting the report described twice per year until further notice from the District.

(3) Each Significant Industrial User other than a Categorical Industrial User must submit to the District twice per year a report describing the nature and concentration of the pollutants which are regulated by this Ordinance. The report shall include the average and maximum daily flows. The District may determine during which months the Significant Industrial User shall submit these reports. If a Local Limit requires compliance with a Best Management Practice or Pollution prevention alternative, the User must submit all documentation necessary for the District to determine the User's compliance status. The User's report must be based



on sampling and analysis performed during the six-month reporting period and in accordance with the techniques described in 40 CFR Part 136 and amendments thereto. At the District's discretion, this sampling and analysis may be performed by the District.

(4) Each Non-Significant Categorical Industrial User must submit to the District annually a certification statement stating that the facility never Discharged more than 100 gallons of total categorical Wastewater on any given day during the reporting period.

(5) Zero Dischargers must submit an annual certification statement to the District stating no Discharge of Process Wastewater occurred during the reporting period.

(d) Compliance Schedule for the Installation of Technology. The District may require a Discharger to develop a compliance schedule for the installation of technology to meet applicable Pretreatment Standards or Requirements. Requiring a compliance schedule for the installation of technology is not conditioned on a determination that a violation of the Discharger's Wastewater Discharge Permit or this Ordinance has occurred. The compliance schedule for installation of technology shall require a Discharger to submit periodic progress reports.

(e) Report on Compliance with Categorical Deadline. Each Categorical Industrial User shall submit a report within 90 days after the final date for compliance, or upon commencement of Discharge, whichever comes later, which contains flow and pollutant measurements, a certification of whether Pretreatment Standards are being met consistently, and if not, a description of needed additional operations and maintenance or pretreatment. The report on compliance with categorical deadline, if required, shall be reviewed by an authorized representative of the User, and certified to by a qualified professional, indicating whether Pretreatment Standards are being met on a consistent basis, and, if not, whether additional operation and maintenance and/or additional pretreatment is required for the User to meet the Pretreatment Standards and Requirements.

(f) Notice of Violation/Resampling Report. If sampling by a User indicates a violation of the User's Wastewater Discharge Permit, this Ordinance, or a Pretreatment Standard or Requirement, the User shall notify the District within 24 hours of becoming aware of the violation. The User shall also repeat the sampling and analysis and submit the results of the repeat analysis to the District within 30 days of becoming aware of the violation, unless the District samples the User between the time of the initial sampling and the time



when the User receives the results of this sampling. Within five (5) days of detecting such violation, the User shall, unless waived by the District, submit a detailed written report describing the cause(s) of the Discharge and the measures to be taken by the User to prevent similar future occurrences. Such notification shall not relieve the User of any expense, loss, damage, or other liability which may be incurred as a result of damage to the POTW, natural resources, or any other damage to person or property, nor shall such notification relieve the User of any fines, penalties, or other liability which may be imposed pursuant to this ordinance.

(g) Slug Control Plan. The District may require a plan which outlines Discharge practices, including non-routine batch Discharges, describes stored chemicals, and contains procedures both to notify the District immediately of Slug Discharges and to prevent adverse impacts from any accidental spill.

(h) Notice of Potential Problems. Each Industrial User shall notify the District immediately of all Discharges that could cause problems to its Wastewater treatment facility, including any slug loadings, as defined by 40 CFR 403.5(b), by the Industrial User.

(i) Notification of Changed Conditions. Each Industrial User shall promptly notify the District in advance of any substantial change in the volume or character of pollutants in their Discharge, including the listed or characteristic hazardous wastes for which the Industrial User has submitted initial notification under 40 CFR 403.12(p), and immediate notification of any changes that affect the potential for a Slug Discharge.

(j) Notification of Hazardous Waste Discharge.

(1) All Industrial Users discharging any substance which, if otherwise disposed of, would be a hazardous or acutely hazardous waste under 40 CFR 261, must comply with the reporting requirements of 40 CFR 403.12(p)(1) and (3) unless exempted under the provisions of 40 CFR 403.12(p)(2).

(2) In the case of any notification made under Section (1) above, the Industrial User shall certify that it has a program in place to reduce the volume and toxicity of hazardous wastes generated to the degree it has determined to be economically practical. The District may accept a copy of a hazardous waste reduction or minimization plan otherwise required by law, as compliance with this requirement.



(k) Monitoring Programs. The Director may require of Dischargers such technical or monitoring programs, including the submission of periodic reports, as the Director deems necessary, provided that the burden, including costs, of such programs and reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained therefrom. The Discharger shall pay the applicable District charge for the monitoring program, in addition to the Wastewater disposal charge and other charges established by the District. The monitoring program may require the Discharger to conduct a sampling and analysis program of a frequency and type specified by the Director or as required by the General Pretreatment Regulations to demonstrate compliance with prescribed Wastewater Discharge limits. The Discharger may:

(1) Conduct their own sampling and analysis program provided the Discharger demonstrates to the Director that they have the necessary qualifications and facilities to perform the work; or

(2) Engage a private consulting firm or laboratory, certified under the Environmental Laboratory Accreditation Program.

(3) The Director may authorize a waiver where a pollutant is neither present nor expected to be present in the Discharge as specified in 40 CFR 403.12(e)(2).

(l) Additional Monitoring Report. If a Significant Industrial User monitors any regulated pollutant at the appropriate sampling location more frequently than required by the District, using approved sampling and analytical methods, the results of this monitoring shall be reported to the District.

(m) Inspection Facilities. The Director may require any non-residential Discharger to construct, at their own expense, a sampling facility or inspection maintenance hole together with necessary related measuring and sampling equipment, in accordance with construction standards and specifications of the Public Agency owning the Community Sewer. The sampling facility or inspection maintenance hole shall be constructed on the Sewer Lateral of the Discharger and within the public right of way at a location approved by the District and the Public Agency owning the Community Sewer, provided that the Director may permit the installation of such facilities on the Premises of the Discharger at a location which will permit District access to the facility at all times. Construction shall be completed within 60 days of written notification from the Director, unless such time is extended by the Director for good cause. The Director may require the Discharger to install such sampling facilities or inspection maintenance holes on each side sewer.



(n) Pretreatment. Pretreatment systems or devices may be required by the Director to treat Wastewater prior to Discharge to the Community Sewer when it is necessary to restrict or prevent the Discharge to the Community Sewer of Wastewater having constituents in violation of the prohibitions or exceeding the limits established by this Ordinance, or to distribute Wastewater Discharges over a period of time. All pretreatment systems or devices shall be approved by the Director but such approval shall not relieve a Discharger of the responsibility for taking all steps necessary to comply with Wastewater limitations established by the District. All required pretreatment equipment shall be installed and operated at the Discharger's expense. Any subsequent changes in the pretreatment facilities or method of operation shall be reported to and be acceptable to the District.

(o) Protection From Accidental or Slug Discharge. Each Discharger shall provide protection from accidental or Slug Discharge of prohibited materials or other Wastes regulated by this Ordinance. Such facilities shall be provided and maintained at the Discharger's expense. These facilities shall be approved by the Director but such approval shall not relieve the Discharger from the responsibility of modifying the facilities to provide the protection necessary to meet the requirements of this Section.

(p) Representative Data. All data submitted in reports or applications shall be representative of conditions during the reporting period.

(q) The Director may require the submission of any other reports not specified in this Section, as deemed necessary by the District to determine a User's compliance status with local, state and federal limits or requirements.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 3

SIGNATURE REQUIREMENT

(a) All reports and permit applications received or required under these regulations, including BMR, reports on compliance with Categorical Pretreatment Standard deadlines (90-day compliance reports), and periodic reports on continued compliance, shall be signed:



(1) by a responsible corporate officer, if the User submitting the reports is a corporation. For purposes of this paragraph, a responsible corporate officer means:

(A) a president, secretary, treasurer, or vice president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or

(B) the manager of one or more manufacturing, production, or operating facilities, if authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures and the manager is authorized to make management decisions which govern the operation of the regulated facility, including having the explicit or implicit duty to

(i) make major capital investment recommendations;

(ii) initiate and direct other comprehensive measures to assure long-term compliance with environmental laws and regulations; and

(iii) ensure that the necessary systems are established or actions taken to gather complete and accurate information for control mechanism requirements.

(2) by a general partner or proprietor if the User submitting the reports is a partnership or sole proprietorship, respectively; or

(3) by a duly authorized representative of the individual designated in paragraph (1) or (2) of this Section if:

(A) The authorization is made in writing by the individual designated in paragraph (1) or (2);

(B) The authorization specifies either an individual or a position having responsibility for the overall operation of the facility from which the industrial Discharge originates, such as the position of plant manager, operator of a well, or well field superintendent, or a position of equivalent responsibility, or having overall responsibility for environmental matters for the company; and



(C) The written authorization is submitted to the District.

(4) If an authorization under paragraph (a)(3) of this Section is no longer

valid because a different individual or position has responsibility for the overall operation of the facility, or overall responsibility for environmental matters for the company, a new authorization satisfying the requirements of paragraph (a)(3) of this Section must be submitted to the District prior to or together with any reports to be signed by an authorized representative.

(b) Reports and applications must include the following certification statement:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 4

RETENTION OF RECORDS

All records, including but not limited to all information resulting from any monitoring activities, Discharge reports, permits, self-monitoring data, pretreatment system process control logs, documentation of compliance with BMP requirements, and relevant correspondence (whether or not required by these regulations) must be maintained by the User for a period of not less than three years. Monitoring records shall be included for all samples as specified in 40 CFR 403.12(o)(1). All such records shall be made available for inspection and copying by a duly authorized representative of the District or any other governmental entity having jurisdiction. The retention period may be extended in the case of unresolved litigation or at any time at the direction of the District, the State or EPA.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



SECTION 5

ANALYTICAL AND SAMPLING METHODOLOGY AND PROCEDURES

(a) The method and procedures utilized for all analyses which are reported under the requirements of these regulations shall be as specified by the provisions of 40 CFR Part 136.

(b) The methods and procedures utilized for all sampling performed and/or reported under the requirements of this regulation shall be as specified by the provisions of 40 CFR Part 136.

(c) If 40 CFR Part 136 does not contain sampling or analytical techniques for the pollutant in question, sampling and analyses must be performed in accordance with procedures approved by EPA.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 6

PUBLIC NOTIFICATION OF DISCHARGERS FOUND TO BE IN SIGNIFICANT NONCOMPLIANCE

At least once per year, the District will publish the identities of any Dischargers found to be in Significant Noncompliance. The publication shall occur in a newspaper of general circulation that provides meaningful public notice within the service area of the District.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013)

SECTION 7

CONFIDENTIAL INFORMATION

All information and data obtained from a Discharger in connection with Federal Pretreatment Standards or Local Limits shall be available to the public or other governmental agencies without restriction. Dischargers may request that information provided to the



District in a report, permit application, questionnaire, or in the course of an inspection be treated as confidential. In all such cases, confidential information shall be made available to governmental agencies including the EPA, the State, and the District for use in pending or potential judicial review or enforcement proceedings involving the Discharger providing the information, and may be disclosed to the public where required by the California Public Records Act or other applicable law, in which case the Discharger shall be solely responsible for taking any action necessary to prevent the release of such information. Wastewater constituents and characteristics will not be recognized as confidential information.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 8

DISTRICT INSPECTION

The District may inspect the facilities of any Discharger to ascertain whether the provisions of this Ordinance are being met and the Wastewater Discharge limits are being complied with. Dischargers shall allow the District or its representatives ready access at all reasonable times to all parts of the Premises for the purposes of inspection or sampling or in the performance of any of their duties. Where a Discharger has security measures which would require proper identification and clearance before entry into their Premises, the User shall make arrangements with their security personnel so that, upon presentation of proper identification, District personnel will be permitted to enter without delay for the purposes of performing their specific responsibilities. Such inspection shall be made with the consent of the owner or possessor of such facilities. If the District has been refused access to any part of a Discharger's facility, and is able to demonstrate probable cause to believe that there may be a violation of this Ordinance, or that there is a need to inspect and/or sample as part of the routine inspection and sampling program of the District, then the Director may seek issuance of an inspection warrant or a search warrant, duly issued pursuant to the procedures set forth in Title 13 (commencing with Section 1822.50) of Part 3 of the Code of Civil Procedure; provided, however, that in the event of an emergency affecting the public health or safety such inspection may be made without consent or the issuance of a warrant. To verify the Wastewater flows, characteristics, constituents, and strengths reported by Dischargers, or to determine compliance with this Ordinance, inspection, measurement, and sampling may be conducted from time to time by the District. The District shall have the right to install, maintain, and operate necessary sampling and measuring equipment on the Premises of Discharger.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



SECTION 9

NEW CONNECTIONS

Dischargers will be assigned a Business Classification Code and informed of the applicable prohibitions, limits or conditions, and the applicable rates and charges, governing Wastewater disposal service at the time of application for water service from East Bay Municipal Utility District. All nonresidential Dischargers seeking a new Sewer Lateral connection to a Community Sewer and any new Discharger requiring information prior to applying for water service should contact the Director. The Director will inform the Discharger of the regulations governing Wastewater disposal service and the applicability of requirements for inspection, sampling, or pretreatment facilities.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



TITLE VI – ENFORCEMENT AND PENALTIES

The Director may adopt procedures and rules for the implementation and administration of this Ordinance, including an enforcement response plan. The Director shall enforce the provisions of this Ordinance, including requirements established or permits issued hereunder, as provided herein.

SECTION 1

NOTICES OF VIOLATION

When the Director finds that a Discharger has violated, or continues to violate, any provision of this ordinance, a Wastewater Discharge Permit, a General Permit, an Order issued hereunder, or any other Pretreatment Standard or Requirement, the Director may serve upon that Discharger a written notice of violation. Within five days of the receipt of such notice, an explanation of the violation and a plan for the satisfactory correction and prevention thereof, to include specific required actions, shall be submitted by the User to the Director. Submission of such a plan in no way relieves the Discharger of liability for any violations occurring before or after receipt of the notice of violation. Nothing in this Section shall limit the authority of the Director to take any action, including emergency actions or any other enforcement action, without first issuing a notice of violation.

SECTION 2

DIRECTOR'S ORDERS

(a) Requiring Discharger to Submit Schedule of Remedial or Preventive Measures. When the Director finds that a Discharge of Wastewater is taking place or threatening to take place that violates or will violate prohibitions or limits prescribed by this Ordinance or Wastewater source control requirements or the provisions of a Wastewater Discharge Permit, the Director may require the Discharger to submit for approval of the Director, with such modifications as the Director deems necessary, a detailed time schedule of specific actions the Discharger shall take in order to correct or prevent a violation of requirements.

(b) Issuance of Cease and Desist Orders. When the Director finds that a Discharge of Wastewater is taking place or threatening to take place in violation of



prohibitions or limits of this Ordinance or Wastewater source control requirements or the provisions of a Wastewater Discharge Permit, the Director may issue an Order to cease and desist and direct that those Persons not complying with such prohibitions, limits, requirements, or provisions (1) comply forthwith, (2) comply in accordance with a time schedule set by the Director, or (3) in the event of a threatened violation, take appropriate remedial or preventative action.

(c) Cost Recovery. When the Discharge of Wastewater causes an obstruction, damage, or other impairment to Wastewater Disposal Facilities, the Director may recover costs from the Discharger to correct the problem caused by the Discharger.

(d) Termination of Service. The District may terminate a Wastewater Discharge Permit, Wastewater disposal service, or water service to any Premises if a violation of any provision of this Ordinance pertaining to control of Wastewater is found to exist or if a Discharge of Wastewater causes or threatens to cause a condition of Contamination, Pollution, or Nuisance, as defined in this Ordinance. This provision is in addition to other statutes, rules, or regulations authorizing termination of service for delinquency in payment, or for any other reason.

(e) Appeal Procedures for Director's Orders.

(1) Any Wastewater Discharge Permit holder, Wastewater Discharge Permit applicant, or Discharger aggrieved by an Order issued pursuant to this Section, or a decision that this Ordinance otherwise specifies is subject to Title VI, Section 2(e), may seek relief by filing a written appeal in accordance with this Section.

(2) An appeal must be filed no later than 15 business days from the date notice of the decision was given.

(3) The appellant must submit a written statement with the appeal, signed under penalty of perjury, and containing (i) a description of the Order, or portion of the Order, that is the subject of the appeal, (ii) a description of the specific relief requested, (iii) a detailed statement of facts which the appellant believes entitles the appellant to the relief requested, and (iv) copies of all supporting documentation or other written evidence the appellant wishes the District to consider. The District may require an appeal to be submitted on a District form.



(4) The Director shall designate a District officer or employee with supervisory or managerial authority who will consider the appeal and decide whether to grant relief. The Director's designee may request additional information and the appellant shall provide such requested information within 15 business days or such other time period authorized in writing by the Director's designee. The evidence before the Director's designee shall consist of the written statement and documentation provided by the appellant in support of the appeal, relevant information in the District's files pertaining to the matter, and any other relevant evidence which, in the judgment of the Director's designee, should be considered. The Director's designee shall consider the available evidence in light of this Ordinance's stated purposes and the public's interest in the fair, equitable, and consistent implementation of this Ordinance.

(5) The Director's designee may decide the matter within 15 business days from the receipt of the complete appeal, except if the Director's designee requests additional information the matter may be decided within 15 business days from the deadline to provide such additional information. If the Director's designee does not decide the matter within the above-stated time period, the appeal shall be deemed denied on the first day following that time period. Notice of any decision will be mailed to the Person requesting relief.

(6) Within 30 calendar days after the date of mailing of written notice of any decision granting or denying relief under Subsection (5) of this Section, or within 30 calendar days after the date the appeal is deemed denied, the Person aggrieved by the Order that was the subject of the appeal may submit to the Director a written request for reconsideration. The request for reconsideration must set forth in detail the facts and rationale supporting the request under penalty of perjury. The Director shall either personally consider the request for reconsideration, designate another senior manager or officer of the District to consider the request for reconsideration, or designate an independent hearing officer to consider the request for reconsideration as the circumstances may require.

(7) The Director may act on the request for reconsideration with or without an oral hearing in any manner the Director deems reasonable under the circumstances, except where the Order at issue has the effect of terminating Wastewater service, terminating water service, or revoking the appellant's Wastewater Discharge Permit, in which case an oral hearing shall be held at the appellant's request. Any request for a hearing shall accompany the written request



for reconsideration described in Subsection (6). Failure to submit a request for a hearing in conjunction with the written request for reconsideration shall be deemed a waiver of the right to a hearing.

(8) The Director, or the other designated officer if applicable, shall thereafter issue a final written determination concerning the request for reconsideration. The Director may consider the written appeal made pursuant to Subsection (3); the decision rendered by their designee pursuant to Subsections (4) and (5); the request for reconsideration submitted pursuant to Subsection (6); evidence and argument offered at hearing, if held; relevant information in the District's files pertaining to the matter, and any other relevant evidence which, in the judgment of the Director, should be considered, including any additional information requested by the Director. The Director's decision shall become final and binding at the time the Director acts on the request for reconsideration, except to the extent the action is the subject of an administrative complaint for penalties as provided in Section 3 of this Title. Notice of the Director's action will be mailed to the appellant within 5 business days after the action.

(9) Unless the Director orders otherwise, any appealed Order or action shall remain in effect and binding upon the appellant while the appeal, including any reconsideration thereof, remains pending.

(10) Any Person aggrieved by an Order issued pursuant to this Section, or a decision that this Ordinance otherwise specifies is subject to Title VI, Section 2(e), and who wishes to appeal or challenge the Order or decision, or receive other relief from a requirement thereof, must seek review by utilizing all procedures available under this Section, and the failure to do so shall be deemed a failure of the Person subject to the Order to exhaust administrative remedies.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 3

DIRECTOR'S ENFORCEMENT REMEDIES AND PENALTIES

(a) Civil Liability Penalties. Civil liability may be imposed by the Director, a hearing officer designated by the District, or the Board in the manner provided in this Section as follows:



(1) In an amount which does not exceed one thousand dollars (\$1,000) for each day for knowingly or willfully failing or refusing to furnish technical or monitoring reports.

(2) In an amount which does not exceed five thousand dollars (\$5,000) for each day of intentionally or negligently discharging hazardous waste, as defined in Section 25117 of the Health and Safety Code, knowingly falsifying any information provided in any furnished technical or monitoring report.

(3) In an amount which does not exceed ten dollars (\$10) per gallon for Discharges in violation of any of the District's cease and desist or other Orders, or prohibitions issued, reissued, or adopted by the District.

(b) Issuance of Complaints.

(1) The Director may issue a complaint to any Person on whom civil liability may be imposed pursuant to this Ordinance. The complaint shall allege the act or failure to act that constitutes a violation of law, the provision of law authorizing civil liability to be imposed pursuant to this Ordinance, and the proposed civil liability.

(2) The complaint shall be served by personal notice or certified mail on the Person subject to the District's Discharge and reporting requirements, and shall inform the party served that a hearing shall be conducted before a hearing officer appointed by the Director, at a specified date and time, no later than 60 calendar days after the party has been served.

(3) The Person who has been issued a complaint may waive the right to a hearing in writing no later than 10 calendar days following service of notice thereof, in which case the District shall not conduct a hearing and the Person will be deemed to have waived any further right of appeal or hearing and of all subsequent administrative remedies provided in this Title. If the right to a hearing is not timely waived and the Person fails to appear at such hearing, the District shall not conduct the hearing, and the Person failing to appear will be deemed to have waived their right to a hearing and any further right of appeal and of all subsequent administrative remedies provided in this Title. If the right to a hearing is timely waived, or if a party fails to appear at the hearing, the Director may issue a final Order imposing civil liability in the amount proposed in the complaint and serve such final Order by personal notice or certified mail. Under these circumstances the



Director's Order shall become effective and final upon issuance thereof and not subject to further review or appeal or any subsequent administrative remedies provided in this Title, and payment shall be made no later than 30 calendar days following the date of issuance.

(c) Proceeding Before Hearing Officer.

(1) The hearing officer shall be designated by the District. If after the hearing the hearing officer finds that the Person has violated reporting or Discharge requirements, the hearing officer may assess a fine against that Person. In determining the amount of the fine, the hearing officer shall take into consideration all relevant circumstances, including, but not limited to, the extent of harm caused by the violation, the nature and persistence of the violation, the length of time over which the violation occurs and corrective action, if any, attempted or taken by the Discharger.

(2) The hearing officer shall serve the written decision or Order by personal notice or certified mail. Unless appealed as set forth in this Section, the hearing officer's decision or Order setting administrative civil liability shall become effective and final upon issuance thereof, and payment shall be made no later than 30 calendar days from the date the party is served notice of the hearing officer's decision or Order.

(d) Appeal to Board.

(1) Any party dissatisfied with the hearing officer's decision or Order following a complaint issued under Subsection (b) of this Section may appeal that decision or Order to the Board by filing a written appeal setting forth each ground on which the appeal is based. The appeal shall be filed with the Secretary of the District no later than 30 calendar days from the date of personal service or certified mailing of the hearing officer's decision or Order. The failure to timely file an appeal with the Secretary of the District is jurisdictional and shall be deemed a failure to exhaust administrative remedies.

(2) The Board may grant or deny review of the hearing officer's decision or Order upon receipt of a timely appeal.

(3) If the Board denies review of the hearing officer's decision or Order, the hearing officer's decision or Order shall immediately become effective and



final. Unless the hearing officer's decision or Order is appealed as set forth in this paragraph, payment shall be made no later than 30 calendar days from the date the party is served notice of the decision by the Board to deny review. Upon denial of review by the Board, any party dissatisfied with the hearing officer's decision or Order may obtain review of the hearing officer's decision or Order in the superior court by filing in the court a petition for writ of mandate in accordance with Subsection (d)(6) of this Section.

(4) If the Board grants review of the hearing officer's decision or Order, the Board has discretion to do any of the following:

(A) Adopt the hearing officer's decision or Order in its entirety;

(B) Reduce or otherwise mitigate the penalty imposed by the hearing officer's decision or Order and adopt the balance of the proposed decision or Order;

(C) Make technical or other minor changes to the hearing officer's decision or Order (limited to clarifying or similar changes not affecting the factual or legal basis of the hearing officer's decision) and adopt it in its modified form;

(D) Reject the hearing officer's decision or Order and refer the case back to the hearing officer to take further evidence and prepare a revised proposed decision; or

(E) Reject the hearing officer's decision or Order and decide the case itself on the record, with or without taking additional evidence and after affording the parties an opportunity to provide written or oral argument before the Board. If the Board chooses to decide the case itself on the record and finds, after reviewing the record before the hearing officer and any additional evidence and argument accepted, that the Person has violated reporting or Discharge requirements, the Board may assess a fine against that Person. In determining the amount of the fine, the Board shall take into consideration all relevant circumstances, including, but not limited to, the extent of harm caused by the violation, the nature and persistence of the violation, the length of time over which the violation occurs and corrective action, if any, attempted or taken by the Discharger.



(5) The Board shall serve notice of any Order or decision made under Section 3(d) of this Title by personal notice or certified mail. An Order issued by the Board setting administrative civil liability shall become effective and final upon issuance thereof, and payment shall be made no later than 30 calendar days from the date the party is served notice of the Order or decision.

(6) The decision shall be deemed final on the date of mailing by certified mail or personal delivery of the decision by the Board. Judicial review of any decision subject to the provisions of this Section may be had only if the petition for writ of mandate is filed within 90 days after the decision becomes final, in accordance with California Code of Civil Procedure Section 1094.6.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 4

CRIMINAL PENALTIES

(a) Any Person who intentionally Discharges Wastewater in any manner, in violation of any Order issued by the Director, which results in Contamination, Pollution, or a Nuisance, as defined in this Ordinance, is guilty of a misdemeanor and may be subject to criminal penalties of not more than \$1,000 per day for each such violation, including, but not limited to, any violation of Pretreatment Standards or Requirements.

(b) Any Person who knowingly makes any false statement or representation in any record, report, plan, or other document filed with the District, or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required by the District, shall be punished by a fine of not more than twenty-five thousand dollars (\$25,000) or by imprisonment in the county jail for not more than six months, or by both.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 5

CIVIL ENFORCEMENT REMEDIES AND PENALTIES

The District may pursue any of the alternative civil remedies herein against any Discharger who violates the provisions of this Ordinance.



(a) Civil Enforcement Penalties.

(1) Any Person who fails to comply with any Order issued by the District, including Orders related to Pretreatment Standards or Requirements, shall be subject to a civil penalty not to exceed ten thousand dollars (\$10,000) for each day in which the Discharge, violation, or refusal occurs.

(2) Any Person who intentionally or negligently violates any Order issued by the District for violation of rules regulating or prohibiting Discharge of Wastewater which causes or threatens to cause a condition of Contamination, Pollution or Nuisance, as defined in this article, may be liable civilly in a sum not to exceed twenty-five thousand dollars (\$25,000) for each day in which the violation occurs. The attorney of the District, upon request of the Board of Directors of the District, shall petition the Superior Court to impose, assess, and recover such sums.

(b) Injunction. Whenever a Discharge of Wastewater is in violation of the provisions of this Ordinance, including but not limited to violation of a Pretreatment Standard or Requirement, or otherwise causes or threatens to cause a condition of Contamination, Pollution, or Nuisance, or whenever non-Discharge violations occur including failure to submit a required report or failure to allow the District's inspectors access to an industrial facility, the District may petition the Superior Court for the issuance of a preliminary or permanent injunction, or both, as may be appropriate, restraining the continuance of such violations.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



TITLE VII – RESOURCE RECOVERY PROGRAM

SECTION 1

PURPOSE

The Resource Recovery Program was established under the authority of the Municipal Utility District Act to utilize excess capacity at the District’s Main Wastewater Treatment Plant by accepting materials transported by truck, rail, or other means at designated receiving stations. The provisions of this Title apply to the Discharge of hauled or trucked Waste at designated receiving stations, and do not apply to or regulate Discharges to Community Sewers.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 2

REGULATION OF DISCHARGES

Permitted materials may be Discharged into designated receiving stations at District Wastewater facilities provided that such material has been deemed acceptable by the District under Resource Recovery acceptance procedures and has been permitted by the District. Under no circumstances may any Person discharge hazardous waste, as defined under State and Federal regulations, into the designated receiving stations. It is entirely within the District’s discretion to accept or reject any material, permittee, generator, or hauler. The District maintains full discretion on the issuance, terms and conditions, and revocation of permits.

No Person shall Discharge materials through the Resource Recovery Program without first obtaining a Material Acceptance Permit as described in Section 3 of this Title. The District in its discretion may accept Wastes or Wastewater that exceed a Local Limit via the Resource Recovery Program if approved by the District in advance. The District may accept Waste or Wastewater with pH less than 5.5 at designated receiving stations specifically designed to accommodate low pH Waste.

Material determined by the District to be subject to Categorical Pretreatment Standards will be required to meet all applicable rules and the Waste generator will be



classified as a Categorical Industrial User.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 3

PERMIT REQUIREMENTS

All participants in the Resource Recovery Program shall secure a Material Acceptance Permit. The permitting process may include collection of information about the Waste stream and generator; collection of information from the Waste generator, if not the permittee, by District; collection and analysis of samples by generator, permittee, or District; and an evaluation of potential impacts including worker health and safety, plant process impacts, and regulatory impacts to air, liquid and solid Waste permits. Persons seeking a Material Acceptance Permit shall complete and file a District application form accompanied by the applicable District permit fee. The application requires information on Waste characterization including, but not limited to, origin of the Waste, estimated Waste quantity, Waste characteristics including pH, organic analysis, and analysis for other potential pollutants including metals. The application also includes certification of insurance. All permitting decisions shall rest with the Director.

All Material Acceptance Permits shall be subject to all provisions of this Title and all applicable rates and charges established by the District. Material Acceptance Permit conditions may contain any and all of the following: Limits on Waste characteristics, rate, volume, number of loads, time, and location of Discharge; Monitoring and audit program which may include random and unannounced inspections and sampling; Other conditions as deemed appropriate by the Director to ensure compliance with this Ordinance and/or terms and conditions of the permit. Dischargers are prohibited from discharging materials except as expressly provided in the Material Acceptance Permit.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)

SECTION 4

ADMINISTRATION AND ENFORCEMENT

The Director is charged with responsibility for District's Wastewater control program and the administration and enforcement of the provisions of this Ordinance. In order to effectively administer and enforce the provisions of these regulations, the Director



may require any Material Acceptance Permit holder to comply with any or all of the requirements described in Title V Administration, Section 2.

The Director may adopt procedures and rules for the implementation and administration of this Title. The Director shall enforce the provisions of this Title, including requirements established or Material Acceptance Permits issued hereunder as provided herein.

(a) Requiring Permittee to Submit Schedule of Remedial or Preventive Measures. When the Director finds that a Resource Recovery Program participant has violated or will violate prohibitions or limits prescribed by this Ordinance, Wastewater source control requirements, or the provisions of a Material Acceptance Permit, the Director may require the Resource Recovery Program participant to submit for approval of the Director, with such modifications as the Director deems necessary, a detailed time schedule of specific actions the Resource Recovery Program participant shall take in order to correct or prevent a violation of requirements.

(b) Discharge Without a Permit. No Person shall Discharge any substance into a District facility under the Resource Recovery Program without a Material Acceptance Permit.

(c) Violation of Permit Terms and Conditions. When the Director finds that a Discharge of materials is taking place or about to take place in violation of prohibitions or limits of this Ordinance or a Material Acceptance Permit, the Director may direct those Persons not complying with such prohibitions, limits, requirements, or provisions to

(1) comply forthwith,

(2) comply in accordance with a time schedule set by the Director, or

(3) in the event of a threatened violation, take appropriate remedial or preventative action. Discharges in violation of a permit may be fined an amount not to exceed \$10/gallon in addition to direct and indirect costs associated with the Discharge.

(d) Cost Recovery. When the Discharge under the Resource Recovery Program causes an obstruction, damage, or other impairment to Wastewater Disposal Facilities, the Director may recover costs from the Resource Recovery Program participant to correct the problem caused by the Resource Recovery Program participant.



(e) Termination of Material Acceptance Permit. The District may terminate a Material Acceptance Permit at will. Grounds for termination of a Material Acceptance Permit include, but are not limited to, discharging material that deviates from the material described in the Material Acceptance Permit, a violation of this Ordinance pertaining to control of Wastewater, or a Discharge of materials that causes or threatens to cause a condition of Contamination, Pollution, or Nuisance, as defined in this Ordinance. This provision is in addition to other statutes, rules, or regulations authorizing termination of service for delinquency in payment, or for any other reason.

(f) Civil Liability Penalties. Resource Recovery Program participants may be subject to civil liability as described in Title VI, Section 3.

(g) Criminal Penalties. Resource Recovery Program participants may be subject to criminal liability as described in Title VI, Section 4.

(h) Civil Enforcement Remedies and Penalties. The District may pursue any of the alternative civil remedies described in Title VI Section 5 against any Resource Recovery Program participant who violates the provisions of this Ordinance.

(Ord. No. 355-11, 7-12-2011; Ord. No. 377-24 § 2, 08-13-2024)



TITLE VIII - SEVERABILITY

If any provision of this Ordinance, or the application thereof to any Person or circumstance, is held invalid, the remainder of the Ordinance, or the application of such provision to other Persons or circumstances, shall not be affected thereby.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

TITLE IX- EFFECTIVE DATE

This Ordinance shall become effective on September 13, 2024.

(Ord. No. 355-11, 7-12-2011; Ord. No. 358-13 § 2, 7-23-2013; Ord. No. 377-24 § 2, 08-13-2024)

