

# NOTICE AND NECESSARY INFORMATION (NANI)

*This form is to assist compliance with the bulk sewage sludge (biosolids) notification requirements [503.12(f)]. Please note, however, that if the biosolids meet the Exceptional Quality (EQ) criteria, then the notification requirements do not apply. This form can be used by preparers of biosolids to transmit information to land appliers and also by land appliers to transmit information to landowners and lease holders.*

**Facility:** East Bay Municipal Utility District

**Biosolids Type:** Sludge

**Monitoring Period:** From May 1, 2025

To May 31, 2025

**To be completed by PREPARERS of Biosolids**

A. Please provide pollutant concentrations.

Constituent	Concentration Dry Weight (mg/kg) <sup>1</sup>	Pollutant Concentrations (Table 3, 40 CFR 503.13) Monthly Average (mg/kg)	Ceiling Concentrations <sup>2</sup> (Table 1, 40 CFR 503.13) Daily Maximum (mg/kg)
	Arsenic	8.0	41
Cadmium	0.7	39	85
Copper	349.5	1500	4300
Lead	24.9	300	840
Mercury	0.5	17	57
Molybdenum	5.8	N/A <sup>3</sup>	75
Nickel	53	420	420
Selenium	19.9	100	100
Zinc	733	2800	7500
TKN	54,286	N/A	N/A
Ammonia-N	8,571	N/A	N/A
Nitrate-N	5.2	N/A	N/A
Percent Solids	21	N/A	N/A

<sup>1</sup> Dry weights were calculated from wet weights provided in analytical reports.

<sup>2</sup> Biosolids may not be land applied if any pollutant exceeds these values.

<sup>3</sup> EPA has temporarily removed molybdenum limits from Table 3.

**Attached: Analytical Data Report(s): C035777**

B. Class B Pathogen Reduction (40 CFR 503.32) -- Please indicate process performed.

- Geometric mean of 7 fecal coliform samples    
  Aerobic digestion    
  Composting  
 Air drying    
  Lime stabilization  
 Anaerobic digestion    
  PSRP equivalent

C. Vector Attraction Reduction (40 CFR 503.33) -- Please indicate the option performed.

- Option 1: VSR > 38%    
  Option 6: pH ≥ 12 by alkali addition  
 Option 2: Anaerobic Bench scale test, VSR < 17% after 40 days    
  Option 7: Stabilized solids ≤ 75%  
 Option 3: Aerobic Bench scale test, VSR < 15% after 30 days    
  Option 8: Unstabilized solids ≥ 90%  
 Option 4: SOUR ≤ 1.5 mg O2/hr/gram    
  Option 9: Injection within 1 hour  
 Option 5: Temp > 40 °C for 14 days    
  Option 10: Soil incorporation within 6 hours

D. Certification

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

A. Name and Official Title: <b>Kevin R. Dickison, Wastewater Superintendent</b>	B. Area Code and Telephone Number: <b>(510) 287-1502</b>
C. Signature: 	D. Date signed: 9/15/25



## Analytical Results Report

02 July 2025

Kevin Dickison

MS 59

Re: Monthly 503 Biosolids Monitoring

COC# C035777

Report Generated: 07/01/2025 17:30

### Login Performance Summary

- 0 Lost Analyses
- 0 Hold Time Exceedances
- Analytical analyses did not meet the turnaround time

### Report Notes

Composite of C035064, C035173, C035226, C035419, C035496, C035579, C035651, C035741. 8 sets of grabs received for May 2025, composited in lab by ACN on 05/28/2025 at 08:58.

For questions concerning this report, please contact:

Reported By:

Sue Berg

Senior Chemist

Approved By:

Yuyun Shang

Lab Manager



**Samples for C035777**

**Samples Included in the Report**

<b>Sample Number</b>	<b>Sample Type</b>	<b>Sampled Date</b>	<b>Location Name</b>	<b>Sample Name</b>
C035777-01	COMP	May 27 2025 08:15	WWTP DEWATERING - CAKE COMBINED	-



**Samples Results for C035777**

**Sample ID:** C035777-01  
**Site:** WWTP DEWATERING SD-1 Wastewater Treatment Plant : Digested Sludge Dewatering  
**Locator:** CAKE COMBINED (DWKC) Dewatering Building Cake  
**Client:** Monthly 503 Biosolids Monitoring  
**Sample Type:** COMP  
**Date Collected:** May 27 2025 08:15 **Sample Collector:** WWTP OPS  
**Date Received:** May 28 2025 08:58 **Sample Receiver:** A Ng  
**Sample Comments:** Field Comments: Comp Batch: B250528-009; Composite of C035064, C035173, C035226, C035419, C035496, C035579, C035651, C035741. 8 sets of grabs received for May 2025, composited in lab by ACN on 05/28/2025 at 08:58.

Analyte	Qualifier	Result	MDL	RL	Units	DF	Batch	Prepared	Analyzed
---------	-----------	--------	-----	----	-------	----	-------	----------	----------

**Total Solids by SM 2540 G-2015**

**TARGET ANALYTES**

Total Solids		21	0.04	0.15	%		B250530-023		05/30/2025 15:38
Comments: Analyte not available for certification by CA ELAP									

**Ammonia as N by SM 4500-NH3 C-2011**

**TARGET ANALYTES**

Ammonia as N		1800	35	370	mg/kg	250	B250605-021		06/05/2025 09:30
--------------	--	------	----	-----	-------	-----	-------------	--	------------------

**Organic Nitrogen-SOL by SM4500-N ORG C (1997, Calculation)**

**TARGET ANALYTES**

Organic Nitrogen as N, calculated		9600	163		mg/kg		B250613-014		06/13/2025 12:21
-----------------------------------	--	------	-----	--	-------	--	-------------	--	------------------

**Total Kjeldahl Nitrogen As N by EPA 350.1**

**TARGET ANALYTES**

Total Kjeldahl Nitrogen as N		11400	521	948	mg/kg	470	B250602-007		06/03/2025 14:17
------------------------------	--	-------	-----	-----	-------	-----	-------------	--	------------------

**Anions by EPA 300.1A by EPA 300.1-Modified**

**TARGET ANALYTES**

Nitrate as N	U	1.1	1.1	7.5	mg/kg	250	B250530-024	05/30/2025 13:48	05/30/2025 23:53
--------------	---	-----	-----	-----	-------	-----	-------------	------------------	------------------

**SURROGATES**

Dichloroacetate (%)		109			%	250	B250530-024	05/30/2025 13:48	05/30/2025 23:53
---------------------	--	-----	--	--	---	-----	-------------	------------------	------------------

**Mercury by EPA 7471 A**

**TARGET ANALYTES**

Mercury		0.098	0.014	0.042	mg/kg	1.0	B250605-003		06/06/2025 13:33
---------	--	-------	-------	-------	-------	-----	-------------	--	------------------

**Metals by EPA 6010 B**

**TARGET ANALYTES**

Arsenic	E1	1.67	0.20	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
Cadmium	E1	0.15	0.03	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
Chromium		8.41	0.57	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
Copper	B1	73.4	0.08	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
Molybdenum	E1	1.22	0.11	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
Nickel	R1	11.1	0.18	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
Lead	R1	5.22	0.14	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
Selenium		4.18	0.61	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
Zinc		154	0.17	3.58	mg/kg	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38

**INTERNAL STANDARD**

Yttrium (%)		101			%	0.72	B250617-024	06/16/2025 08:45	06/17/2025 13:38
-------------	--	-----	--	--	---	------	-------------	------------------	------------------



**Quality Control for C035777**

Analyte	Qualifier	Result	MDL	RL	Units	Spike Level	Source Result	% REC	% REC Limits	RPD	RPD Limits
<b>Total and Volatile Solids DUP by SM 2540 G-2015, EPA 160.4, B250530-023</b>											
<b>B250530-023 analyzed on 05/30/2025 15:38; Source = C035867-04</b>											
Total Solids		6.2	0.04	0.15	%		6.0			2.3	10
<b>Total and Volatile Solids MB by SM 2540 G-2015, EPA 160.4, B250530-023</b>											
<b>B250530-023 analyzed on 05/30/2025 15:38</b>											
Total Solids	U	0.04	0.04	0.15	%						
<b>Total Kjeldahl Nitrogen As N DUP by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 15:05; Source = C036853-12</b>											
Total Kjeldahl Nitrogen as N		87.9	4.4	8.0	mg/L		90.8			3.2	10
<b>Total Kjeldahl Nitrogen As N LCS by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 13:42</b>											
Total Kjeldahl Nitrogen as N		15.8	1.1	2.0	mg/L	16.0		99	90 - 110		
<b>Total Kjeldahl Nitrogen As N LCSD by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 13:44</b>											
Total Kjeldahl Nitrogen as N		15.7	1.1	2.0	mg/L	16.0		98	90 - 110	0.9	10
<b>Total Kjeldahl Nitrogen As N MB by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 13:32</b>											
Total Kjeldahl Nitrogen as N	U	1.1	1.1	2.0	mg/L						
<b>Total Kjeldahl Nitrogen As N MS by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 15:08; Source = C036853-12</b>											
Total Kjeldahl Nitrogen as N	M1	146	8.8	16.0	mg/L	64.0	90.8	86	90 - 110		
<b>Total Kjeldahl Nitrogen As N QCS by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 13:30</b>											
Total Kjeldahl Nitrogen as N		20.0	1.1	2.0	mg/L	19.9		100	90 - 110		
<b>Total Kjeldahl Nitrogen As N DUP by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 14:05; Source = C036910-01</b>											
Total Kjeldahl Nitrogen as N		11800	514	934	mg/kg		11900			1.1	10
<b>Total Kjeldahl Nitrogen As N LCS by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 13:39</b>											
Total Kjeldahl Nitrogen as N		1860	127	231	mg/kg	1850		100	90 - 110		



**Quality Control for C035777**

Analyte	Qualifier	Result	MDL	RL	Units	Spike Level	Source Result	% REC	% REC Limits	RPD	RPD Limits
<b>Total Kjeldahl Nitrogen As N MB by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 13:35</b>											
Total Kjeldahl Nitrogen as N	U	118	118	216	mg/kg						
<b>Total Kjeldahl Nitrogen As N MS by EPA 350.1, B250602-007</b>											
<b>B250602-007 analyzed on 06/03/2025 14:08; Source = C036910-01</b>											
Total Kjeldahl Nitrogen as N		13700	521	948	mg/kg	1900	11900	94	90 - 110		
<b>Ammonia as N LCS by SM 4500-NH3 C-2011, B250605-021</b>											
<b>B250605-021 analyzed on 06/05/2025 09:30</b>											
Ammonia as N		12	0.14	1.5	mg/L	12		96	90 - 110		
<b>Ammonia as N LOQ by SM 4500-NH3 C-2011, B250605-021</b>											
<b>B250605-021 analyzed on 06/05/2025 09:30</b>											
Ammonia as N		1.5	0.14	1.5	mg/L	1.5		100	50 - 150		
<b>Ammonia as N MB by SM 4500-NH3 C-2011, B250605-021</b>											
<b>B250605-021 analyzed on 06/05/2025 09:30</b>											
Ammonia as N	U	0.14	0.14	1.5	mg/L						
<b>Ammonia as N MS by SM 4500-NH3 C-2011, B250605-021</b>											
<b>B250605-021 analyzed on 06/05/2025 09:30; Source = C035892-01</b>											
Ammonia as N		75	0.70	7.5	mg/L	60	15	100	80 - 115		
<b>Ammonia as N MSD by SM 4500-NH3 C-2011, B250605-021</b>											
<b>B250605-021 analyzed on 06/05/2025 09:30; Source = C035892-01</b>											
Ammonia as N		74	0.70	7.5	mg/L	60	15	98	80 - 115	1.4	10
<b>Ammonia as N LCS by SM 4500-NH3 C-2011, B250605-021</b>											
<b>B250605-021 analyzed on 06/05/2025 09:30</b>											
Ammonia as N		2900	35	380	mg/kg	3000		98	85 - 115		
<b>Ammonia as N MB by SM 4500-NH3 C-2011, B250605-021</b>											
<b>B250605-021 analyzed on 06/05/2025 09:30</b>											
Ammonia as N	U	35	35	380	mg/kg						
<b>Anions DUP by EPA 300.1-Modified, B250530-024</b>											
<b>B250530-024 analyzed on 05/31/2025 01:08; Source = C035777-01</b>											
Nitrate as N	U	1.1	1.1	7.5	mg/kg		1.1			NC	10
Dichloroacetate (%)		110			%		109				



**Quality Control for C035777**

Analyte	Qualifier	Result	MDL	RL	Units	Spike Level	Source Result	% REC	% REC Limits	RPD	RPD Limits
<b>Anions LCS by EPA 300.1-Modified, B250530-024</b>											
<b>B250530-024 analyzed on 05/30/2025 19:27</b>											
Nitrate as N		0.082	0.0044	0.03	mg/kg	0.09		91	85 - 115		
Dichloroacetate (%)		104			%						
<b>Anions LOQ-Modified by EPA 300.1-Modified, B250530-024</b>											
<b>B250530-024 analyzed on 05/30/2025 18:50</b>											
Nitrate as N	E1	0.027	0.0044	0.03	mg/kg	0.03		90	50 - 150		
Dichloroacetate (%)		101			%						
<b>Anions MB by EPA 300.1-Modified, B250530-024</b>											
<b>B250530-024 analyzed on 05/30/2025 18:12</b>											
Nitrate as N	U	0.0044	0.0044	0.03	mg/kg						
Dichloroacetate (%)		109			%						
<b>Anions MS by EPA 300.1-Modified, B250530-024</b>											
<b>B250530-024 analyzed on 05/31/2025 02:24; Source = C035777-01</b>											
Nitrate as N		20	1.1	7.5	mg/kg	22	1.1	91	75 - 125		
Dichloroacetate (%)		106			%		109				
<b>Mercury LCS by EPA 7471 A, B250605-003</b>											
<b>B250605-003 analyzed on 06/06/2025 13:27</b>											
Mercury		0.324	0.014	0.041	mg/kg	0.33		99	80 - 120		
<b>Mercury LCSD by EPA 7471 A, B250605-003</b>											
<b>B250605-003 analyzed on 06/06/2025 13:29</b>											
Mercury		0.330	0.014	0.042	mg/kg	0.33		100	80 - 120	1.9	10
<b>Mercury LOQ by EPA 7471 A, B250605-003</b>											
<b>B250605-003 analyzed on 06/06/2025 13:25</b>											
Mercury	E1	0.040	0.014	0.042	mg/kg	0.042		96	50 - 150		
<b>Mercury MB by EPA 7471 A, B250605-003</b>											
<b>B250605-003 analyzed on 06/06/2025 13:21</b>											
Mercury	U	0.014	0.014	0.042	mg/kg						
<b>Mercury MS by EPA 7471 A, B250605-003</b>											
<b>B250605-003 analyzed on 06/06/2025 13:36; Source = C035777-01</b>											
Mercury		0.432	0.014	0.042	mg/kg	0.33	0.098	100	75 - 125		
<b>Mercury MSD by EPA 7471 A, B250605-003</b>											
<b>B250605-003 analyzed on 06/06/2025 13:38; Source = C035777-01</b>											
Mercury		0.417	0.014	0.042	mg/kg	0.33	0.098	97	75 - 125	3.4	20



**Quality Control for C035777**

Analyte	Qualifier	Result	MDL	RL	Units	Spike Level	Source Result	% REC	% REC Limits	RPD	RPD Limits
---------	-----------	--------	-----	----	-------	-------------	---------------	-------	--------------	-----	------------

**Mercury QCS by EPA 7471 A, B250605-003**

**B250605-003 analyzed on 06/06/2025 13:31**

Mercury		20.0	0.554	1.66	mg/kg	19		104	80 - 167		
---------	--	------	-------	------	-------	----	--	-----	----------	--	--

**Metals DUP by EPA 6010 B, B250617-024**

**B250617-024 analyzed on 06/17/2025 13:41; B250616-008 prepared on 06/16/2025 08:45; Source = C035777-01**

<b>Arsenic</b>	<b>E1</b>	<b>1.54</b>	0.20	3.58	mg/kg		1.67			7.9	20
<b>Cadmium</b>	<b>E1</b>	<b>0.16</b>	0.03	3.58	mg/kg		0.15			2.0	20
<b>Chromium</b>		<b>8.71</b>	0.57	3.58	mg/kg		8.41			3.6	20
<b>Copper</b>		<b>74.1</b>	0.08	3.58	mg/kg		73.4			1.0	20
<b>Molybdenum</b>	<b>E1</b>	<b>1.24</b>	0.08	3.58	mg/kg		1.22			1.3	20
<b>Nickel</b>	<b>R1</b>	<b>8.48</b>	0.18	3.58	mg/kg		11.1			26.5	20
<b>Lead</b>	<b>R1</b>	<b>6.88</b>	0.14	3.58	mg/kg		5.22			27.5	20
<b>Selenium</b>		<b>3.79</b>	0.61	3.58	mg/kg		4.18			9.8	20
<b>Zinc</b>		<b>155</b>	0.17	3.58	mg/kg		154			0.6	20
Yttrium (%)		101			%		101				

**Metals LCS by EPA 6010 B, B250617-024**

**B250617-024 analyzed on 06/17/2025 13:22; B250616-008 prepared on 06/16/2025 08:45**

Arsenic		103	0.28	4.97	mg/kg	99		103	80 - 120		
Cadmium		20.0	0.04	4.97	mg/kg	20		100	80 - 120		
Chromium		50.8	0.79	4.97	mg/kg	50		102	80 - 120		
Copper		49.5	0.12	4.97	mg/kg	50		100	80 - 120		
Molybdenum		20.0	0.10	4.97	mg/kg	20		101	80 - 120		
Nickel		48.8	0.24	4.97	mg/kg	50		98	80 - 120		
Lead		49.9	0.20	4.97	mg/kg	50		100	80 - 120		
Selenium		52.9	0.84	4.97	mg/kg	50		106	80 - 120		
Zinc		50.4	0.23	4.97	mg/kg	50		101	80 - 120		
Yttrium (%)		104			%						

**Metals LCSD by EPA 6010 B, B250617-024**

**B250617-024 analyzed on 06/17/2025 13:24; B250616-008 prepared on 06/16/2025 08:45**

Arsenic		102	0.28	4.96	mg/kg	99		102	80 - 120	1.1	10
Cadmium		19.8	0.04	4.96	mg/kg	20		100	80 - 120	0.9	10
Chromium		50.3	0.79	4.96	mg/kg	50		101	80 - 120	1.0	10
Copper		48.6	0.12	4.96	mg/kg	50		98	80 - 120	1.8	10
Molybdenum		19.8	0.10	4.96	mg/kg	20		100	80 - 120	1.3	10
Nickel		48.3	0.24	4.96	mg/kg	50		97	80 - 120	0.9	10
Lead		49.7	0.20	4.96	mg/kg	50		100	80 - 120	0.5	10
Selenium		53.0	0.84	4.96	mg/kg	50		107	80 - 120	0.2	10
Zinc		49.9	0.23	4.96	mg/kg	50		100	80 - 120	1.0	10
Yttrium (%)		103			%						

**Metals MB by EPA 6010 B, B250617-024**

**B250617-024 analyzed on 06/17/2025 13:13; B250616-008 prepared on 06/16/2025 08:45**

Arsenic	U	0.28	0.28	4.96	mg/kg						
Cadmium	U	0.04	0.04	4.96	mg/kg						
Chromium	U	0.79	0.79	4.96	mg/kg						
<b>Copper</b>	<b>E1</b>	<b>0.17</b>	0.12	4.96	mg/kg						
Molybdenum	U	0.10	0.10	4.96	mg/kg						
Nickel	U	0.24	0.24	4.96	mg/kg						



**Quality Control for C035777**

Analyte	Qualifier	Result	MDL	RL	Units	Spike Level	Source Result	% REC	% REC Limits	RPD	RPD Limits
Lead	U	0.20	0.20	4.96	mg/kg						
Selenium	U	0.84	0.84	4.96	mg/kg						
Zinc	U	0.23	0.23	4.96	mg/kg						
Yttrium (%)		104			%						

**Metals MS by EPA 6010 B, B250617-024**

**B250617-024 analyzed on 06/17/2025 13:44; B250616-008 prepared on 06/16/2025 08:45; Source = C035777-01**

Arsenic		76.2	0.20	3.56	mg/kg	71	1.67	104	75 - 125
Cadmium		14.7	0.03	3.56	mg/kg	14	0.15	102	75 - 125
Chromium		45.3	0.56	3.56	mg/kg	36	8.41	104	75 - 125
Copper		112	0.08	3.56	mg/kg	36	73.4	107	75 - 125
Molybdenum		15.7	0.08	3.56	mg/kg	14	1.22	101	75 - 125
Nickel		44.1	0.18	3.56	mg/kg	36	11.1	93	75 - 125
Lead		41.3	0.14	3.56	mg/kg	36	5.22	101	75 - 125
Selenium		43.9	0.60	3.56	mg/kg	36	4.18	112	75 - 125
Zinc		189	0.17	3.56	mg/kg	36	154	99	75 - 125
Yttrium (%)		100			%		101		

**Metals QCS by EPA 6010 B, B250617-024**

**B250617-024 analyzed on 06/17/2025 13:27; B250616-008 prepared on 06/16/2025 08:45**

Arsenic		173	0.68	12.1	mg/kg	180		96	80 - 126.7
Cadmium		175	0.10	12.1	mg/kg	200		88	80 - 120
Chromium		186	1.93	12.1	mg/kg	210		89	80 - 120
Copper		196	0.29	12.1	mg/kg	230		86	78.6 - 120
Molybdenum		109	0.26	12.1	mg/kg	120		94	77.1 - 120
Nickel		91.9	0.60	12.1	mg/kg	110		85	78.7 - 120
Lead		229	0.48	12.1	mg/kg	260		88	78.2 - 120
Selenium		114	2.06	12.1	mg/kg	120		98	80 - 120
Zinc		236	0.57	12.1	mg/kg	260		90	80 - 120
Yttrium (%)		109			%				



### Qualifiers and Definitions

- B1 Analyte detected in method blank at or above acceptance criteria. The analytical batch meets acceptance criteria for reporting.
- E1 Concentration estimated. Analyte detected below reporting limit (RL) but above MDL. For SIP, E1=DNQ, Estimated Concentration.
- M1 The MS recovery was outside acceptance limits due to possible matrix interference. The analytical batch meets accuracy criteria for reporting.
- NC RPD not calculable. Result less than MDL.
- R1 The RPD was outside laboratory acceptance limits due to possible matrix interference. The analytical batch meets criteria for reporting.
- U Analyte not detected.

Qualifiers for subcontract work – see parameter comment for description  
Corrections for dilutions for matrix effects applied to the MDL and RL.



### QC Types and Definitions

DUP	Duplicate Sample
LCS	Laboratory Control Sample
LCSD	Laboratory Control Sample Duplicate
LOQ	Limit of Quantitation
MB	Method Blank
MS	Matrix Spike
MSD	Matrix Spike Duplicate
QCS	Quality Control Sample



East Bay Municipal Utility District Laboratory Services Division Chain of Custody Record



COC #: C035777	Project Title: Monthly 503 Biosolids Monitoring TAT: Standard	Client PM: Kevin Dickison Lab PM: Sue Berg Job #:	Received Date/Time: 05/28/2025 08:58 Received By: Alvin Ng Sampled By: WWTP OPS Due Date: 06/25/2025
-------------------	--	---	---

Date	Time	Site/Locator	Sample ID	Type	Matrix	ID	Type	Tests Required
05/27/2025	08:15	WWTP DEWATERING - CAKE COMBINED	C035777-01	COMP	Solid			+SAMP KIT
						-01A	CUP	TS
						-01B	PLSTL	Ammonia: Titr-SOL, Organic Nitrogen-SOL, SFA TKN-SOL
						-01C	PLSTL	EPA 7471 Hg, EPA 6010-SOL (As,Cd,Cr,Cu,Mo,Ni,Pb,Se,Zn)
						-01D	JARS	+SAVE 180
						-01E	JARS	EPA 300.1-SOL (NO3)

Field Comments: Comp Batch: B250528-009; Composite of C035064, C035173, C035226, C035419, C035496, C035579, C035651, C035741. 8 sets of grabs received for May 2025, composited in lab by ACN on 05/28/2025 at 08:58.

Field Instructions: Sample composited by lab staff from grabs collected during the month.

Sample External Comments:

Total Containers for: C035777	5
-------------------------------	---



**C035777 Sample Acceptance Report**

Received: 05/28/2025 08:58  
Received By: Alvin Ng

Chain-of-Custody		Comments
Chilled During Transport?	Yes	
Missing or incorrect information	No	
Mode of receipt	Drop-off Room	
Shipping Slip?	No	

Containers		Comments
BACT (120 mL) lot number	Add lot no	
BACTL (290 mL) lot number	Add lot no	
Container and label are legible and match COC?	Yes	
Correct container used with field preservation?	Yes	
Received within holding times?	Yes	
Sufficient volume, undamaged, or uncontaminated?	Yes	

Intent to chill		Comments
<b>Cooler: 1</b>		
Corrected Temp (° C)	7.2	
IR Thermometer Number	IR #17	
Representative temperature taken from	-01	
Uncorrected Temp (° C)	7.1	
Visible ice formed inside sample container?	No	

Acceptance		Comments
PM notified?	N/A	
Samples meet acceptance requirements?	Yes	



COC: C035777

**Sample Acceptance Preservation Report**

Report Generated: 05/28/2025 09:05

No preservation upon sample receipt required for this sampling event



EAST BAY MUNICIPAL UTILITY DISTRICT - LABORATORY SERVICES DIVISION

Analysis: Composite	Batch: B250528-009
Analyst: ACN	Composited Date/Time 05/28/2025 08:58

Sample ID	Samp Type	Sampled Date/Time	Amount (g)
C035064-01	WWTP DEWATERING - CAKE C 03	05/02/2025 8:05	100
C035173-01	WWTP DEWATERING - CAKE C 04	05/06/2025 9:45	100
C035226-01	WWTP DEWATERING - CAKE C 05	05/09/2025 7:58	100
C035419-01	WWTP DEWATERING - CAKE C 04	05/13/2025 8:04	100
C035496-01	WWTP DEWATERING - CAKE C 04	05/16/2025 8:00	100
C035579-01	WWTP DEWATERING - CAKE C 04	05/20/2025 8:15	100
C035651-01	WWTP DEWATERING - CAKE C 05	05/23/2025 7:52	100
C035741-01	WWTP DEWATERING - CAKE C 05	05/27/2025 8:15	100