



Request For Proposal (RFP) No. FMC734-26-01
for Sobrante Water Treatment Plant Clarifiers Replacement

Addendum

To bidders under RFP No. FMC734-26-01 “Sobrante Water Treatment Plant Clarifiers Replacement”.

Notice is hereby given that RFP No. FMC734-26-01 “Sobrante Water Treatment Plant Clarifiers Replacement” of the East Bay Municipal Utility District has been revised as set forth below.

1. Planetary gear system or direct coupled reducing gears can be acceptable. If motors are vertical, modifications to the hatch may be required, and should be included in the bid.
2. The drawings included in the RFP package are for reference to the existing system only, to ensure compatibility with the new drive. No new control or electrical panels are required.
3. Height from the top of the existing drive plate to the hatch door is approximately 36”. The dimensions should be verified by The Contractor before manufacturing can begin.
4. List of contractors, per request, from our Contract Equity vendor list:

10112951	Anvil Builders Inc.	1395 Evan Ave, 2nd Floor	San Francisco, CA, 94124	Tran, Hien	415-285-5000	estimating@anvilbuilders.com
10132553	Garney Pacific Inc.	324 E 11th St, Suite E2	Tracy, CA, 95376	Mata, Feliciano	925-800-1848	fmata@garney.com
10122851	Flatiron West Inc.	1200 Concord Ave, Suite 465	Concord, CA, 94520	Simon, Lillian	682-213-6322	lsimon@flatironconstructs.com
10030607	Blocka Construction Inc.	445 Boulder Ct	Pleasanton, CA, 94566	Blocka, Jean	510-657-3686	bids@blockainc.com
RAP57000	Ranger pipelines Inc.	P O. Box 24109	San Francisco, CA, 94124	Ishihara- Rivas, Irene	415-848-3291	irene@rangerpipelines.com

5. The due date for the bid packet for RFP No. FMC734-26-01 “Sobrante Water Treatment Plant Clarifiers Replacement” has been extended to Tuesday, May 26th at 2:00 p.m.

Contact Tracy Barrow with any questions or if any additional information is required:

Office (510) 287-0627, or email: tracy.barrow@ebmud.com

THIS ADDENDUM MUST BE SUBMITTED WITH THE UPDATED PROPOSAL FORM.

Tracy Barrow
Construction and Maintenance Scheduler