

February 20, 2025

ADDENDUM NO. 1

TO PROSPECTIVE BIDDERS UNDER REQUEST FOR QUOTATION (RFQ) NO. 2511
FLEXIBLE TEMPORARY WATER DISTRIBUTION HOSE

Notice is hereby given that RFQ No. 2511 of the East Bay Municipal Utility District has been revised as set forth and responses provided to bidder questions below.

Exhibit E, Specification 33 14 13.57, page 7, Paragraph C has been added below.

2.4 REDUCER FITTINGS:

- A. Provide the following reducer fittings:
 - 1. 12" x 8", quantity shall be 18.
 - 2. 12"x 10", quantity shall be 18.
- B. Acceptable Manufacturer and Product: Victaulic Style 50-C concentric reducers, or equal as approved by the Engineer.
- C. Couplings for attaching the reducer fittings to hose end sections shall be Victaulic Style 307, or equal as approved by the Engineer, in 12-in sizes. Quantity shall be 36.

QUESTIONS AND ANSWERS

Q: Good afternoon, the bid does not say what materials are acceptable for the REDUCER FITTINGS, the 12X8 and 12X10. Is aluminum or iron acceptable?

A: The reducer fittings shall be NSF 61 certified. The acceptable product called out in the spec (Victaulic 50-C) is ductile iron, which is required to be furnished with NSF 61-certified lining and gasket for compliance with the Specifications.

Q: Regarding the stainless-steel couplings, our manufacturer uses aluminum for the *external* clamping collars to control costs. All components in contact with water will

remain stainless steel. The aluminum clamps are solely on the outside of the hose.

Could you please confirm if this meets your requirements?

A: It is acceptable that the non-wetted clamps are made of aluminum.

THIS ADDENDUM MUST BE SUBMITTED WITH THE BID

Thank you for your cooperation.

Becky Sharpe for KKS

Kelley K. Smith
Manager of Purchasing