

March 20, 2025

ADDENDUM NO. 1

TO PROSPECTIVE BIDDERS UNDER RFQ NO. 2513, “LIQUID AMMONIUM SULFATE FOR WATER TREATMENT PLANTS (WTP)”

Notice is hereby given that RFQ No. 2513 of the East Bay Municipal Utility District has been revised as set forth below:

1. On the cover page of the RFQ, **the statement under the Bids Due announcement is revised as shown below** (to match the actual bid opening time of 2:00 p.m.):

All bid submissions hand delivered or mailed (USPS, FedEx, UPS, etc.) to the address or PO Box noted below and must be received no later than **2:00 p.m.** on the bid due date.

2. Under I. STATEMENT OF WORK, A. SCOPE, **page 3, 1st paragraph, 1st sentence is revised** as shown below:

It is the intent of these specifications, terms, and conditions to describe requirements to furnish and deliver liquid ammonium sulfate 40% solution (LAS) **by weight** on an as-needed basis to the District's various drinking water treatment plants.

3. Under I. STATEMENT OF WORK, A. SCOPE, page 3, 3rd paragraph is deleted and **replaced as shown below** (wherein reference to AWWA standard B302-23 has been removed):

Under this proposal, the Contractor must furnish LAS f.o.b. destination as specified herein.

4. Under I. STATEMENT OF WORK, C. SPECIFICATIONS, Page 3, Article 1. is deleted and **replaced** as shown below (wherein reference to AWWA standard B302-23 has been removed):

1. **The liquid ammonium sulfate 40% solution supplied under the contract shall be within the concentration range 38-40% solution by weight and**

RFQ No. 2513 - Addendum No. 1

March 20, 2025

Page 2 of 2

clear to pale yellow with no visible solids. The LAS to be supplied shall be suitable for use in the treatment of potable water.

THIS ADDENDUM MUST BE SUBMITTED WITH THE BID

Thank you for your cooperation.

A handwritten signature in black ink, appearing to read 'Kelley K. Smith', with a stylized flourish at the end.

Kelley K. Smith

Manager of Purchasing