

January 15, 2026

ADDENDUM NO. 2

TO PROSPECTIVE BIDDERS UNDER RFQ NO. 2614, "NON-LEADED BRASS WATER SERVICE FITTINGS"

Notice is hereby given that RFQ No. 2614 of the East Bay Municipal Utility District has been revised as set forth below:

1. The date of the **bid opening has been changed to January 28, 2026**. Time and place remain the same.
2. Under SPECIFIC REQUIREMENTS, page 4, Section 4. MATERIAL, paragraphs a. and b. are deleted and **replaced as shown below**:

4. MATERIAL

- a. All metal components in contact with water shall be non-leaded, copper-**bismuth** alloys, UNS No. C89520 or C89833 **or copper-silicon alloy** **UNS No. C87850**. The term non-leaded means the maximum lead content shall be 0.25% or less.
- b. The product overall must meet the conditions specified in NSF-61 Annex G. Other alloys will be considered and may be approved by the District under the following conditions:
 - i. The alloy is specified in ASTM standards.
 - ii. The alloy has a use history in waterworks or similar applications.
 - iii. The alloy has the following minimum performance requirements:
 - Mechanical Properties: materials shall have the following minimum mechanical properties: 25 ksi tensile strength, 14 ksi yield strength and 6% elongation in 2".
 - Corrosion Resistance: materials shall not exceed 100 **micro-meter** maximum dezincification depth in the ISO 6509 test.

- Stress Corrosion Cracking Resistance: materials shall pass one of the following – ISO 6957 at pH 9.5., ASTM B858 at pH 9.5 or ASTM G37 (minimum 20 foot pounds torque and 150 hours minimum time limit).

THIS ADDENDUM LETER MUST BE SUBMITTED WITH THE BID

Thank you for your cooperation.



Kelley K. Smith
Manager of Purchasing