

April 23, 2026

ADDENDUM NO. 1

TO PROSPECTIVE BIDDERS UNDER RFQ NO. 2607, “MAIN WASTEWATER TREATMENT PLANT (MWWTP) SECONDARY REACTORS BUTTERFLY VALVES”

Notice is hereby given that RFQ No. 2607 of the East Bay Municipal Utility District has been revised as set forth below:

1. Under EXHIBIT F8 – SECTION 33 12 16.34 HYDRAULIC AND PNEUMATIC VALVE ACTUATORS, PART 2 – PRODUCTS, **after** Article 2.1.G, page 11, **add paragraph H. as shown below:**


“H. Manufacturer shall provide zerk fittings to lubricate parts that can seize, including the declutching mechanism/lever.”

2. Under EXHIBIT F8 – SECTION 33 12 16.34 HYDRAULIC AND PNEUMATIC VALVE ACTUATORS, PART 2 – PRODUCTS, **Article 2.4.D**, page 12, **is deleted and replaced as shown below:**

“D. Manual gear overrides shall be designed to produce the required operating torque, plus an appropriate safety factor (1.25 minimum), with a maximum rim pull of **40 lb. on the rim of the handwheel for the valve seating or unseating load and a maximum rim pull of **40 lb.** on the rim of the handwheel at any point through the travel for the valve running load, unless otherwise specified in the purchase documents.”**

THIS ADDENDUM LETTER MUST BE SUBMITTED WITH THE BID

Thank you for your cooperation.



Kelley K. Smith
Manager of Purchasing