

February 26, 2019

ADDENDUM NO. 1

TO PROSPECTIVE BIDDERS UNDER RFQ NO. 1915, "LARGE DIAMETER VALVES AND ASSOCIATED EQUIPMENT" NOTICE IS HEREBY GIVEN THAT RFQ NO. 1915 OF THE EAST BAY MUNICIPAL UTILITY DISTRICT HAS BEEN REVISED AS SET FORTH BELOW:

RFQ No. 1915

On EXHIBIT D, SPECIFICATION 33 12 16.27 AWWA Ball Valves, Page 6, delete TABLE B and replace with updated TABLE BELOW.

Table B Flow Criteria					
Controllable Flow Point	Flow [gpm]	Upstream Pressure [psig]	Downstream Pressure [psig]	Approximate Cv [gpm]	Approximate Valve Position [% open]
Claremont Outage Maximum	30,553	32	29.7	19,750	57
Normal Maximum	34,720	30.4	29.5	35,000	70
<u>Notes</u> 1. Fluid is treated water at 60 deg F.					

THIS ADDENDUM MUST BE SUBMITTED WITH THE BID.



Kelley Smith  
Purchasing Manager