



SECTION 31

WATER EFFICIENCY REQUIREMENTS

These regulations identify the types of water efficiency requirements for water service and the procedure for notification to Applicants that water efficiency measures are required. The most water-efficient requirement of EBMUD, local, state or federal regulations apply.

A. DETERMINATION OF FEASIBILITY OF WATER EFFICIENCY MEASURES

The District will review applications for new standard services and determine the applicability of, and compliance with, water-efficiency requirements. Applicants for expanded service shall be required to meet the water-efficiency requirements for all new water service facilities and may be required to retrofit existing water service facilities or uses to comply with these requirements. Applicant shall maintain design documents and construction and installation records and furnish a copy of said documents and records to the District upon request. The District may inspect the installation of water efficiency measures to verify that the items are installed and performing to the required water use levels. The Applicant or their representative may be present during any District inspection.

B. WATER EFFICIENCY REQUIREMENTS FOR NEW DEVELOPMENT OR EXPANDED SERVICE

Water service shall not be furnished to any Applicant for new or expanded service, or for any change in customer classification (such as a change from industrial to commercial, residential to commercial, or the like) that includes new or retrofitted water using equipment, unless all the applicable water-efficiency measures hereinafter described in this Section 31 have been reviewed and approved by the District. All the applicable and required water-efficiency measures shall be installed at Applicant's expense.

C. INDOOR WATER USE

a. Residential Water Service.

Toilets shall be high-efficiency or dual flush models rated and (third party) tested at a maximum average flush volume of 1.28 gallons per flush (gpf), and be certified as passing a 350 gram or higher flush test as established by the U.S. Environmental Protection Agency WaterSense Specification or other District-accepted third party testing entity. No flush or conversion devices of any other kind shall be accepted.

- a. Showerheads shall be individually plumbed and have a maximum rated flow of 2.0 gallons per minute or less and be limited to one showerhead per shower stall of 2,500 sq. inches in area or less. Installation of flow restrictors in existing showerheads does not satisfy this requirement.
- b. Lavatory faucets shall have aerators or laminar flow control devices (i.e., orifices) with a maximum rated flow of 1.5 gallons per minute or less.



SECTION 31

WATER EFFICIENCY REQUIREMENTS
(continued)

- c. Kitchen faucets shall have aerators or laminar flow control devices (i.e., orifices) with a maximum rated flow of 2.2 gallons per minute or less.
- d. Clothes washing machines shall be front loading horizontal axis or top loading models with a water factor rating of 4.5 or less. A water factor rating of 4.5 means a maximum average water use of 4.5 gallons per cubic foot of laundry.
- e. Dishwashers rated as standard size (i.e. 307 kWh/year) shall use less than or equal to 5.0 gallons/cycle. Dishwashers rated as compact size (i.e., 222 kWh/year) shall use less than or equal to 3.5 gallons/cycle.

b. Non-Residential Water Service.

- a. Toilets shall be high-efficiency or dual flush models rated and (third-party) tested at a maximum average flush volume of 1.28 gallons per flush (gpf), and be certified as passing a 350 gram or higher flush test as established by the U.S. Environmental Protection Agency WaterSense Specification or other District-accepted third party testing entity. Pressure-assisted type toilets shall be high-efficiency rated at a maximum 1.0 gpf. No flush or conversion devices of any other kind shall be accepted.
- b. Urinals shall have a maximum rated flow of 0.125 gpf or less, or be zero water consumption urinals.
- c. Showerheads shall be individually plumbed and have a maximum rated flow of 2.0 gallons per minute or less, and be limited to one showerhead per shower stall of 2,500 sq. inches in area or less. Installation of flow restrictors in existing showerheads does not satisfy this requirement.
- d. Lavatory faucets shall have aerators or laminar flow control devices (i.e., orifices) with a maximum rated flow of 1.5 gallons per minute or less.
- e. Kitchen faucets shall have aerators or laminar flow control devices (i.e., orifices) with a maximum rated flow of 2.2 gallons per minute or less.
- f. Laundry washing machines shall be front loading horizontal axis or top loading models with both: (1) a maximum water factor rating of 4.5 or less. A water factor of 4.5 means a maximum average water use of 4.5 gallons per cubic foot of laundry or less.
- g. Cooling towers not utilizing recycled water shall be equipped with recirculating systems and operate at a minimum of five (5) cycles of concentration. Newly constructed cooling towers shall be operated with conductivity controllers, as well as make up and blowdown meters.



SECTION 31

WATER EFFICIENCY REQUIREMENTS
(continued)

- h. Food steamers in all food service facilities shall be boiler less or self-contained models using ≤ 3.0 gallons per hour where applicable.
- i. Ice machines shall be air-cooled or use no more than 20 gallons of water per 100 pounds of ice and shall be equipped with a recirculating cooling unit.
- j. Commercial refrigeration shall be air-cooled or if water-cooled, must have a closed looped system. No once through, single pass systems are permitted.
- k. Pre-Rinse Dishwashing Spray Valves shall have a maximum rated flow of 1.6 gpm or less.
- l. Dishwashers or ware washing equipment shall be currently labeled an EnergyStar rated water efficient model meeting the maximum water consumption limits as specified in the table below:

Machine Type	High Temp Requirements	Low Temp Requirements
Under Counter	≤ 0.86 GPR	≤ 1.19 GPR
Stationary Single Tank Door	≤ 0.89 GPR	≤ 1.18 GPR
Pot, Pan, and Utensil	≤ 0.58 GPSF	≤ 0.58 GPSF
Single Tank Conveyor	≤ 0.70 GRP	≤ 0.79 GPR
Multiple Tank Conveyor	≤ 0.54 GRP	≤ 0.54 GRP
Single Tank Flight Type	$\leq \text{GPH} \leq 2.975x + 55.00$	$\leq \text{GPH} \leq 2.975x + 55.00$
Multiple Tank Flight Type	$\leq \text{GPH} \leq 4.96x + 17.00$	$\leq \text{GPH} \leq 4.96x + 17.00$

*GRP (gallons per rack); GPSF (gallons per square foot); GPH (gallons per hour)

- m. Vehicle wash facilities shall reuse a minimum of 50% of water from previous vehicle rinses in subsequent washes.

D. OUTDOOR WATER USE (All Applicants)

1. Landscaping.

- a. Plans with design details including plants, irrigation, grading and hydrozones shall be submitted to the District for review and approval by District for compliance with these Regulations prior to installation of a water meter. Detailed landscaping plans are required for any new or retrofitted landscaping greater than 2,500 square feet of landscaped area. Applicants with less than 2,500 square feet of landscaped area shall be required to complete a check list provided by the District including a planting and irrigation diagram for review by the District.



SECTION 31

WATER EFFICIENCY REQUIREMENTS
(continued)

Landscaping shall include water efficient technology and use best management practices to reduce the annual supplemental irrigation requirement to the lowest practical amount not to exceed 70% of reference evapotranspiration for the landscaped area.

- b. Ornamental Turf areas shall be limited to no more than 25% of the total landscaped area. Exceptions may be granted, in the sole discretion of the District, for approved drought tolerant grasses and for approved recreational areas. Turf is not permitted in any area or portion of an area with a dimension of less than eight feet on any side and shall meet precipitation rate requirements for slopes greater than 25 percent.
- c. Non-turf areas shall be native or climate-appropriate species classified as low or very-low water use in the California Department of Water Resources publication Water Use Classification of Landscape Species (WUCOLS). Up to 20% of the non-turf landscaped area may have a medium or high water requirement as long as they are appropriately grouped together and irrigated separately. High and medium water use plants shall not be irrigated on the same zone that includes any low or very-low water use plant. The surface area of pools and water features shall be included in the 20% of non-turf medium or high water use landscaped area calculation.
- d. Mulch: A minimum 3-inch layer of mulch shall be specified for non-turf planting areas unless there is a horticultural reason not to mulch.

2. Irrigation.

- a. Irrigation Efficiency. Irrigation systems shall be designed, installed and operated to avoid overspray and runoff onto any adjacent hardscape or planting area. Irrigation systems shall be designed, installed and operated at the lowest practical amount of water not to exceed 70% of reference evapotranspiration for the landscaped area.
- b. Automatic, self-adjusting irrigation controllers shall be required on all irrigation systems with three or more valves or landscaped areas of 1,000 sq. ft. or more and shall automatically activate and deactivate the irrigation system based on changes in the weather or soil moisture. [SS1]
- c. Overhead sprinklers and spray heads shall not be permitted in any landscaped area or portion of an area with a dimension of less than eight feet on any side and shall be offset a minimum of 24 inches away from impervious paving. All sprinklers and other emission devices shall have matched precipitation rates within each control valve or zone. Landscape design best practices shall include distribution uniformity, head-to-head spacing and other conditions as required by regulation and/or ordinance.
- d. Valves and circuits shall be separated hydrozoned based on plant water requirement (including varying root depth), sun exposure, top and bottom of slope, and irrigation rate as applicable.



SECTION 31

WATER EFFICIENCY REQUIREMENTS
(continued)

- e. Dedicated Irrigation Meter shall be required for irrigated landscaped area of 5,000 square feet or more.
 - f. Certificate of Completion.
Applicant shall submit a landscape audit report verifying installation and irrigation efficiency per approved design on a form provided by the District.
3. **Swimming pools and spas.**
- a. Covers are required for all pools and spas. Public health and safety exemptions may be granted as solely determined by District.

E. PENALTIES/CONSEQUENCES

Failure of Applicant to conform to this Regulation and these water-efficiency requirements stated herein may result in:

- 1. A requirement to resubmit water service application and water-efficiency plan at Applicant's expense until District approves water service.
- 2. District's inability to release water meter(s) for installation and inability to activate account until water-efficiency plan is approved by District.