

November 15, 2018

ADDENDUM NO. 1

TO PROSPECTIVE BIDDERS UNDER RFQ NO. 1906, "VARIOUS STEEL MORTAR-LINED PIPE FITTINGS"

Notice is hereby given that RFQ No. 1906 of the East Bay Municipal Utility District has been revised as set forth below:

1) Specification

DELETE the following Article I.C.2.b in its entirety:

Mortar lining shall conform to AWWA Specification C104-95 EXCEPT for Page 3, Section 4.7 Table 1 entitled "Thickness of Lining." Table should read, "ALL LINING SHOULD RANGE FROM 1/8" TO 1/4" THICK." NO SUBSTITUTION OF MATERIAL ORDERED IS ALLOWED WITHOUT PRIOR WRITTEN CONSENT OF THE DISTRICT.

And **REPLACE** WITH the following:

Mortar lining shall conform to AWWA Standard C205-12 EXCEPT for Page 7, Section 4.4.2 Table 1. Thickness of cement mortar lining shall conform to EBMUD Standard Drawings 1216-A or 1884-A.

2) Standard Drawing 309-EA

DELETE the following Note 6 in Standard Drawing 309-EA in its entirety:

Fittings shall be lined in accordance with AWWA C-104 with lining thickness indicated on DWG's. 1216-A or 1884-A. Prior to mortar lining, abrasive blast interior of fittings to a "commercial blast cleaning" SSPC-SP-6.

And **REPLACE** WITH the following:

Fittings shall be lined with cement mortar in accordance with AWWA Specification C205-12 EXCEPT for Page 7, Section 4.4.2 Table 1. Thickness of cement mortar lining shall conform to

RFQ No. 1906
Addendum No. 1
November 15, 2018
Page 2

EBMUD Standard Drawings 1216-A or 1884-A. No cement mortar
lining holdback at ends.

THIS ADDENDUM MUST BE SUBMITTED WITH THE BID.



Andrew A. Akelman
Manager of Purchasing

AA:sr